

OSHPD Office of Statewide Health Planning and Development



Facilities Development Division
400 R Street, Suite 200
Sacramento, California 95811-6213
(916) 440-8300
Fax (916) 324-9188
www.oshpd.ca.gov/fdd

Facilities Development Division
700 North Alameda Street, Suite 2-500
Los Angeles, CA 90012
(213) 897-0166
Fax (213) 897-1122
www.oshpd.ca.gov/fdd

HEALTH CARE FACILITY LOCAL FIRE AUTHORITY FIRE ALARM ANNUNCIATION APPROVAL 2013 CALIFORNIA BUILDING STANDARDS CODE

HOSPITAL: _____ OSHPD PROJECT #: _____

ADDRESS: _____

The Office of Statewide Health Planning and Development (OSHPD) reviews fire alarm installations for compliance with the minimum requirements of NFPA Standard No. 72-2013 and Chapter 9 of the 2013 California Fire Code (CFC). Minimum requirements include zoning for the purpose of annunciation in accordance with 2013 CFC Section 907.6.3. OSHPD does not review projects for compliance with zoning and remote annunciation requirements of the statutory local fire authority.

Prior to final plan approval of the above-identified project, review and approval by the local fire authority, of the following requirements, is requested.

LOCAL FIRE AUTHORITY ANNUNCIATION REQUIREMENTS:

1. Visible annunciation shall be provided at an approved remote location where deemed necessary by the enforcing agency. 2013 CFC, Sec. 907.6.3.1.1.
2. Fire alarm annunciation shall be further divided into zones where deemed necessary by the enforcing agency. 2013 CFC, Sec. 907.6.3, Item 7.

LOCAL FIRE AUTHORITY APPROVAL:

For the purpose of annunciation, zoning and the location(s) of the remote annunciator panel(s) are in accordance with the requirements of this statutory fire authority.

Fire Authority: _____

Address: _____

Phone: _____ Email: _____

Authorized Fire Authority Representative: _____

Date: _____ Title: _____



OSHPD Office of Statewide Health Planning and Development

Facilities Development Division
400 R Street, Suite 200
Sacramento, California 95811-6213
(916) 440-8300
Fax (916) 324-9188
www.oshpd.ca.gov/fdd

Facilities Development Division
700 North Alameda Street, Suite 2-500
Los Angeles, CA 90012
(213) 897-0166
Fax (213) 897-1122
www.oshpd.ca.gov/fdd

**INSTRUCTIONS
HEALTH CARE FACILITY
LOCAL FIRE AUTHORITY FIRE ALARM ANNUNCIATION APPROVAL
2013 CALIFORNIA BUILDING STANDARDS CODE**

The Office of Statewide Health Planning and Development (OSHPD) reviews fire alarm projects for compliance with NFPA Standards in accordance with 2013 California Building Code (CBC), Chapter 35 and the 2013 California Fire Code (CFC), Chapter 9. In addition to the specific requirements of the NFPA Standards and the 2013 CFC, annunciation, zoning and the location of remote annunciators are dependent upon site specific conditions and the requirements of the local fire authority.

In order to facilitate the review and approval process, the following performance standards should be considered when designing and preparing a fire alarm system submittal.

1. Remote annunciator panels shall be located in locations approved by the local fire authority.
2. Annunciation shall be zoned in accordance with the requirements of the local fire authority.
3. The local fire authority may require annunciation by an indicator lamp, alphanumeric display, printout or other approved means.

Requirements pertaining to the location and arrangement of remote fire alarm annunciation varies from jurisdiction to jurisdiction and from facility to facility within each jurisdiction. Documentation of local fire authority approval must be submitted to OSHPD prior to OSHPD approval.

To facilitate review and compliance with local requirements, submit a completed Health Care Facility Local Fire Authority Fire Alarm Annunciator Approval with each fire alarm submittal for new construction and new fire alarm installations. A construction document clearly indicating the approval of the local fire authority is also acceptable.