



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD PREAPPROVAL OF
MANUFACTURER'S CERTIFICATION (OPM)

OFFICE USE ONLY

APPLICATION #: OPM-0412-13

OSHPD Preapproval of Manufacturer's Certification (OPM)

Type: ☒ New ☐ Renewal ☐ Update to Pre-CBC 2013 OPA Number: _____

Manufacturer Information

Manufacturer: PREMIER MOUNTS

Manufacturer's Technical Representative: Tiffany Dozier

Mailing Address: 2620 Palisades Drive, Corona, CA. 92882

Telephone: On File Email: On File

Product Information

Product Name: P-Series Monitor Wall Mounts

Product Type: Other mechanical and electrical components

Product Model Number: P2642F, P2642T, P4263F, P4263T, P5080F, P5080T

General Description: Tilting/Non-Tilting Low Profile Monitor Wall Mounts

Applicant Information

Applicant Company Name: EASE Co.

Contact Person: Jonathan Roberson, S.E.

Mailing Address: 5877 Pine Ave. Suite 210, Chino Hills, CA. 91709

Telephone: (909) 606-7622 Email: J.Roberson@EASECo.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant: [Signature] Date: 4/4/17

Title: Principal Engineer Company Name: EASE Co.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY
OSH-FD-700 (REV 12/16/15)

OSHPD

Page 1 of 2



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Registered Design Professional Preparing Engineering Recommendations

Company Name: EASE Co.
Name: Jonathan Roberson, S.E. California License Number: S4197
Mailing Address: 5877 Pine Ave. Suite 210, Chino Hills, CA. 91709
Telephone: 909-606-7622 Email: J.Roberson@EASECo.com

OSHDP Special Seismic Certification Preapproval (OSP)

- ☐ Special Seismic Certification is preapproved under OSP-
(Separate application for OSP is required)
☒ Special Seismic Certification is not preapproved

Certification Method(s)

- ☐ Testing in accordance with: ☐ ICC-ES AC156 ☐ FM 1950-16
☐ Other* (Please Specify): _____

*Use of criteria other than those adopted by the California Building Standards Code, 2016 (CBSC 2016) for component supports and attachments are not permitted. For distribution system, interior partition wall, and suspended ceiling seismic bracings, test criteria other than those adopted in the CBSC 2016 may be used when approved by OSHDP prior to testing.

- ☒ Analysis
☐ Experience Data
☐ Combination of Testing, Analysis, and/or Experience Data (Please Specify): _____

List of Attachments Supporting the Manufacturer's Certification

- ☐ Test Report ☒ Drawings ☒ Calculations ☐ Manufacturer's Catalog
☐ Other(s) (Please Specify): _____

OFFICE USE ONLY – OSHDP APPROVAL VALID FOR CBC 2016 & ALL PRE-2016 CODE BASED PROJECTS

Signature: William Staehlin Date: 11-15-2017
Print Name: William Staehlin
Title: SSE
Condition of Approval (if applicable): _____

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





**EQUIPMENT ANCHORAGE
& SEISMIC ENGINEERING**

5877 Pine Ave, Ste. 210
Chino Hills, CA. 91709
Phn: (909) 606-7622

Office of Statewide Health Planning and Development
PREAPPROVAL OF MANUFACTURER'S CERTIFICATION
OPM-0412-13

THIS PREAPPROVAL CONFORMS TO THE 2016 CALIFORNIA BUILDING CODE

MANUFACTURER: **PREMIER MOUNTS**
EQUIPMENT NAME: **P-SERIES MONITOR MOUNTS**

Sheet: 1 of 8
Date: 8/16/17

GENERAL NOTES

1. THIS OSHPD PREAPPROVAL OF MANUFACTURER'S CERTIFICATION (OPM) IS BASED ON THE 2016 CBC. THE DEMANDS (DESIGN FORCES) FOR USE WITH THIS OPM SHALL BE BASED ON THE 2016 CBC
2. THIS DOCUMENT MAY ONLY BE USED WITH THE EXPRESS WRITTEN CONSENT OF THE MANUFACTURER LISTED ABOVE FOR THE SPECIFIC PROJECT SITE AND INTERIOR INSTALLATION LOCATION. THIS DOCUMENT IS INVALID WITHOUT SUCH CONSENT.
3. THIS PREAPPROVAL CONFORMS TO THE 2016 CALIFORNIA BUILDING CODE WHERE S_{ds} IS NOT GREATER THAN 2.20
4. FORCES PER ASCE 7-10 SECTION 13.3.1, EQUATIONS 13.3-1, 13.3-2 & 13.3-3,
WHERE $S_{ds} = 2.20$, $a_p = 1.0$, $I_p = 1.5$, $R_p = 1.5$, $z/h \leq 1$ AT CONCRETE WALL. SEE FOLLOWING SHEETS FOR Ω .
5. THIS PREAPPROVAL COVERS ONLY THE SUPPORTS AND ATTACHMENTS OF THE EQUIPMENT TO THE STRUCTURE.
6. ALL DESIGN FORCES SHOWN ON THE DRAWINGS ARE FACTORED LOADS THAT SHALL BE USED FOR STRENGTH DESIGN.
7. CONCRETE WALL VALID FOR DEMANDS SHOWN AT ANY ELEVATION (i.e. $z/h \leq 1$)
8. **RESPONSIBILITIES OF THE STRUCTURAL ENGINEER OF RECORD OF THE BUILDING**
 - A. PROVIDE SUPPORTING STRUCTURE TO SUPPORT WEIGHTS AND FORCES SHOWN IN ADDITION TO ALL OTHER LOADS.
 - B. VERIFY THAT THE INSTALLATION IS IN CONFORMANCE WITH THE 2016 CBC AND WITH THE DETAILS, MATERIAL AND GAGE OF THE UNIT WHERE ATTACHMENTS ARE MADE AGREE WITH THE INFORMATION SHOWN ON THE PREAPPROVAL DOCUMENTS.
 - C. VERIFY THAT PROJECT SPECIFIC VALUES OF S_{ds} & z/h RESULT IN SEISMIC FORCES (E_h , E_v) THAT DO NOT EXCEED THE VALUES ON THE DETAILS.
 - D. VERIFY THAT THE CONCRETE WALL TO WHICH THE EQUIPMENT IS ANCHORED MEETS THE REQUIREMENTS OF THE APPLICABLE ICC ESR.
 - E. VERIFY THAT THE ANCHORS ARE AN ADEQUATE DISTANCE FROM ANY CONCRETE WALL EDGES OR OPENINGS (SEE TYPICAL DETAIL ON SHEET 2).
 - F. VERIFY THAT ALL NEW OR EXISTING ANCHORS ARE AN ADEQUATE DISTANCE FROM THE UNIT ATTACHMENTS AND CHECK FOR INTERACTION WHERE OTHER ANCHORS ARE WITHIN 18" OR $6h_{ef}$ FROM THIS UNIT'S ANCHORS.
 - G. DESIGN BACKING BARS, STUDS, ETC. WHICH THE UNITS ARE ATTACHED TO AS NOTED ON THE DRAWINGS.



PREMIER MOUNTS

P-SERIES MONITOR MOUNTS

DES. J. ROBERSON

JOB NO. 11-1703

DATE 8/16/17

SHEET

2

OF 8 SHEETS

9. EXPANSION ANCHORS:

- A. ATTACHMENT IS TO BE MADE WITH THE ANCHORS LISTED BELOW AND INSTALLED AS DESCRIBED IN THE CORRESPONDING ICC REPORT.

Anchor Diameter	Concrete Type	Min. f'c (psi)	Anchor Type	ICC Report No.	Min. Embed.	Min. Spacing	Min. Edge Dist.	Min. Conc. Thickness	Torque Test	Direct Tension
1/4"	Normal Weight	3000	Hilti Kwik HUS	ESR-3027	1.92"	3.5"	12"	5"	N/A	779 lb

- B. THIS PREAPPROVAL ALLOWS FOR UP TO A MAXIMUM OF 2 ADJACENT CONCRETE WALL EDGES, 12" AWAY MINIMUM (i.e. - CORNER). SEE ADJACENT DETAIL FOR ADDITIONAL MINIMUM ALLOWABLE CONCRETE EDGE DISTANCES.

- C. TESTING OF CONCRETE SCREW ANCHORS PER 2016 CBC, 1910A.5: TESTING SHALL BE DONE IN THE PRESENCE OF THE SPECIAL INSPECTOR AND A REPORT OF THE TEST RESULTS SHALL BE SUBMITTED TO OSHPD


- (i) AFTER AT LEAST 24 HOURS HAVE ELAPSED SINCE INSTALLATION, DIRECT PULL TENSION TEST OR TORQUE TEST AT LEAST 50% OF THE ANCHORS.

- (ii) ACCEPTANCE CRITERIA:

- DIRECT TENSION TEST: THE ANCHOR SHOULD HAVE NO OBSERVABLE MOVEMENT AT THE TEST LOAD. A PRACTICAL WAY TO DETERMINE OBSERVABLE MOVEMENT IS THAT THE WASHER BECOMES LOOSE.

- (iii) IF ANY ANCHOR FAILS, TEST ALL ANCHORS.

- D. AVOID DAMAGING EXISTING STEEL REINFORCING IN CONCRETE WALL WHEN INSTALLING CONCRETE SCREW ANCHORS



TYPICAL CONCRETE EDGE DETAIL

BY: William Staehlin



PREMIER MOUNTS

P-SERIES MONITOR MOUNTS

DES. **J. ROBERSON**

JOB NO. **11-1703**

DATE **8/16/17**


SHEET

3

OF **8** SHEETS

SEISMIC SUPPORTS & ATTACHMENTS

WALL MOUNTED



NOTES:

1. **FORCES ARE DETERMINED PER 2016 CALIFORNIA BUILDING CODE AND ASCE 7-10**

STRENGTH DESIGN IS USED. ($S_{DS} = 2.20$, $a_p = 1.0$, $I_p = 1.5$, $R_p = 1.5$, $\Omega_o = 1.5$, $z/h \leq 1$)

HORIZONTAL FORCE (E_h) = $2.64 W_p$

HORIZONTAL FORCE (E_{mh}) = $3.96 W_p$ (FOR CONCRETE ANCHORAGE)

VERTICAL FORCE (E_v) = $0.44 W_p$

- CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THIS PREAPPROVAL ENCOMPASSES ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.
- SEE GENERAL NOTES: SHEETS 1 AND 2.



PREMIER MOUNTS

P-SERIES MONITOR MOUNTS

DES. J. ROBERSON

JOB NO. 11-1703


DATE 8/16/17

SHEET


4

OF 8 SHEETS

SEISMIC SUPPORTS & ATTACHMENTS



STEEL STUD WALL SECTION (P5080F MOUNT SHOWN)



WOOD STUD WALL SECTION (P5080F MOUNT SHOWN)

UNIT	SELF WEIGHT (lb)	MAX MONITOR WEIGHT (lb)	"A" (in.)	"B" (in.)	"C" (in.)	T _u (lb)	V _u (lb)	# OF SCREWS
P2642F	10	130	11.66	4.18	3.64	138	114	4
P4263F	12	175	18.66	4.22	3.6	181	154	4
P5080F	19	300	34.98	4.24	3.58	156	132	8



PREMIER MOUNTS

P-SERIES MONITOR MOUNTS

DES. J. ROBERSON

JOB NO. 11-1703


DATE 8/16/17

SHEET

5

OF 8 SHEETS

SEISMIC SUPPORTS & ATTACHMENTS




ELEVATION AT WALL PLATE

(P5080F MOUNT SHOWN)

UNIT	SELF WEIGHT (lb.)	MAX MONITOR WEIGHT (lb.)	"A" (in.)	"B" (in.)	"C" (in.)	Tu (lb.)	Vu (lb.)	# OF SCREWS
P2642F	10	130	11.66	4.18	3.64	182	159	4
P4263F	12	175	18.66	4.22	3.6	239	214	4
P5080F	19	300	34.98	4.24	3.58	205	183	8

USE 4- 1/4" ϕ HILTI HUS-EZ
SCREW ANCHORS W/
OVERSIZED WASHERS
(MIN. EMBED. (Net) = 1.92")
(UNLESS OTHERWISE
NOTED, SEE SCHED)
TO CONCRETE WALL

WALL MOUNTED



CONCRETE WALL SECTION



PREMIER MOUNTS

P-SERIES MONITOR MOUNTS

DES. J. ROBERSON

JOB NO. 11-1703

DATE 8/16/17


SHEET

6

OF 8 SHEETS

SEISMIC SUPPORTS & ATTACHMENTS

WALL MOUNTED



NOTES:

1. **FORCES ARE DETERMINED PER 2016 CALIFORNIA BUILDING CODE AND ASCE 7-10**


STRENGTH DESIGN IS USED. ($S_{DS} = 2.20$, $a_p = 1.0$, $I_p = 1.5$, $R_p = 1.5$, $\Omega_0 = 1.5$, $z/h \leq 1$)

HORIZONTAL FORCE (E_h) = $2.64 W_p$

HORIZONTAL FORCE (E_{mh}) = $3.96 W_p$ (FOR CONCRETE ANCHORAGE)

VERTICAL FORCE (E_v) = $0.44 W_p$

- CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THIS PREAPPROVAL ENCOMPASSES ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.
- STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.
- SEE GENERAL NOTES: SHEETS 1 AND 2.



PREMIER MOUNTS

P-SERIES MONITOR MOUNTS

DES. J. ROBERSON

JOB NO. 11-1703


DATE 8/16/17

SHEET


7

OF 8 SHEETS

SEISMIC SUPPORTS & ATTACHMENTS



STEEL STUD WALL SECTION
(P5080T MOUNT SHOWN)



WOOD STUD WALL SECTION
(P5080T MOUNT SHOWN)

UNIT	SELF WEIGHT (lb.)	MAX MONITOR WEIGHT (lb.)	"A" (in.)	"B" (in.)	"C" (in.)	Tu (lb.)	Vu (lb.)	# OF SCREWS
P2642T	12	130	11.66	4.73	3.09	181	127	4
P4263T	15	175	18.66	4.74	3.08	124	85	8
P5080T	22	300	34.98	4.77	3.05	199	145	8



PREMIER MOUNTS

P-SERIES MONITOR MOUNTS

DES. **J. ROBERSON**

JOB NO. **11-1703**


DATE **8/16/17**

SHEET

8

OF **8** SHEETS

SEISMIC SUPPORTS & ATTACHMENTS




ELEVATION AT WALL PLATE
(P5080T MOUNT SHOWN)

UNIT	SELF WEIGHT (lb.)	MAX MONITOR WEIGHT (lb.)	"A" (in.)	"B" (in.)	"C" (in.)	Tu (lb.)	Vu (lb.)	# OF SCREWS
P2642T	12	130	11.66	4.73	3.09	235	180	4
P4263T	15	175	18.66	4.74	3.08	303	241	4
P5080T	22	300	34.98	4.77	3.05	259	205	8

USE 4- 1/4"Ø HILTI HUS-EZ SCREW ANCHORS W/ OVERSIZED WASHERS (MIN. EMBED. (h_{ef}) = 1.92") (UNLESS OTHERWISE NOTED, SEE SCHED) TO CONCRETE WALL

WALL MOUNTED



CONCRETE WALL (3000 PSI MIN) BY STRUCTURAL ENGINEER OF RECORD

CONCRETE WALL SECTION

