



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: [X] Yes [] No

Design Basis of Equipment or Components (Fp/Wp) = See table 1b

SDS (Design spectral response acceleration at short period, g) = See table 1b

ap (In-structure equipment or component amplification factor) = See table 1b

Rp (Equipment or component response modification factor) = See table 1b

Omega_0 (System overstrength factor) = See table 1b

Ip (Importance factor) = 1.5

z/h (Height factor ratio) = See table 1b

Equipment or Component Natural Frequencies (Hz) = See attached

Overall dimensions and weight (or range thereof) = See table 1a

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: [] Yes [X] No

Design Basis of Equipment or Components (V/W) =

SDS (Design spectral response acceleration at short period, g) =

SD1 (Design spectral response acceleration at 1 second period, g) =

R (Response modification coefficient) = OSP-0049-10

Omega_0 (System overstrength factor) =

Cd (Deflection amplification factor) = BY: Timothy J Piland

Ip (Importance factor) = 1.5

Height to Center of Gravity above base = DATE: 09/13/2019

Equipment or Component Natural Frequencies (Hz) =

Overall dimensions and weight (or range thereof) =

Tank(s) designed in accordance with ASME BPVC, 2015: [] Yes [X] No

List of Attachments Supporting Special Seismic Certification

[X] Test Report(s) [] Drawings [] Calculations [X] Manufacturer's Catalog

[] Other(s) (Please Specify): Equipment Matrix, Merger Letter/Document

OSHPD Approval (For Office Use Only) - Approval Expires on December 31, 2022

Signature: [Signature] Date: September 13, 2019

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to: SDS (g) = See Above z/h = See Above

Condition of Approval (if applicable):

