### OFFICE USE ONLY APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP) APPLICATION #:** OSP - 0132 - 10 **OSHPD Special Seismic Certification Preapproval (OSP) Manufacturer Information** Manufacturer: West-Com Nurse Manufacturer's Technical Representative: Joseph Wherity Mailing Address: 2200 Cordelia Rd., Fairfield, CA 94534 Telephone: (707) 428-5900 ext 222 Email: jwerity@westcall.com **Product Information** Product Name: Novus, Odyssey, and Endeavor Product Type: Hospital Communication Systems Novus 36/24/0x, Novus 18/22/0x, WOC-8500, EV-32, 64, 96 w/SMC, Novus HRM, I-Dome Product Model Number: HRM (List all unique product identification numbers and/or part numbers) Nurse Call Infrastructure and Head End Control Terminal equipment. General Description: Mounting Description: Wall mounted **Applicant Information** Applicant Company Name: West-Com Nurse Call Systems Inc. Contact Person: Joseph Wherity Mailing Address: 2200 Cordelia RD., Fairfield, CA 94534 Telephone: (707) 428-5900 ext 222 Email: jwerity@westcall.com I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 8/8/17 Title: Director of Technical Services Company Name: West-Com Nurse Call Systems, Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





Page 1 of 3



### OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

California Licensed Structural Engineer Responsible for the Engineering and Test	Report(s)
Company Name: _Buehler & Buehler, Structural Engineers, Inc.	
Name: Scott Hooker, S.E. California License Number: S3	937
Mailing Address: 600 Q Street, Suite 200, Sacramento, CA 95811	
Telephone: (916) 443-0303 Email: shooker@bbse.com	
Supports and Attachments Preapproval	
<ul> <li>Supports and attachments are preapproved under OPM-         (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments are not preapproved</li> </ul>	attachments is required)
Certification Method	
<ul> <li>☐ Testing in accordance with:</li> <li>☐ Other (Please Specify):</li> </ul>	
Testing Laboratory	
Company Name: ANCO Engineers	
Contact Name: Conor Byrne	
Mailing Address: 1965A 33 <sup>rd</sup> Street, Boulder, CO 80304	
Telephone: (303) 443-7580 Email: conor@ancoengineers.com	



Page 2 of 10



### OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: ☐ Yes ☐ No
Design Basis of Equipment or Components (F <sub>p</sub> /W <sub>p</sub> ) = 1.15
S <sub>DS</sub> (Design spectral response acceleration at short period, g) = 1.54
a <sub>p</sub> (In-structure equipment or component amplification factor) = 2.5
R <sub>p</sub> (Equipment or component response modification factor) =6.0
$\Omega_0$ (System overstrength factor) =1.0
I <sub>p</sub> (Importance factor) = 1.5
z/h (Height factor ratio) = 1.0
Equipment or Component Natural Frequencies (Hz) = See attached
Overall dimensions and weight (or range thereof) = See attached
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:   Yes  No
Design Basis of Equipment or Components (V/W) =
S <sub>DS</sub> (Design spectral response acceleration at short period, g) =
S <sub>D1</sub> (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient ) =
$\Omega_0$ (System overstrength factor) =
C <sub>d</sub> (Deflection amplification factor) =
I <sub>p</sub> (Importance factor) =
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☐ No
List of Attachments Supporting Special Seismic Certification
Other(s) (Please Specify): Previous OSP and original Operability test witness documents
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
1/1 00 Date: September 20, 2017
Signature: Date: September 20, 2017
Print Name: Timothy J. Piland Title: SSE
Special Seismic Certification Valid Up to : $S_{DS}(g) = 1.54$ $z/h = 1$
Condition of Approval (if applicable):

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"









#### **Table 1. Certified Product List**

Model Number	Cabinet	Tested/ Interpolated	Length (in)	Width (in)	Height (in)	Operating Weight (lbs)
NV HRM	1212	Extrpolated	6	12	12	15
I-Dome HRM	1212	UUT-1	6	12	12	15
NV PSM/1	1822	Interpolated	6	22	18	42.5
NV PSM/2	1822	Interpolated	6	22	18	42.5
NV PSM/3	1822	Interpolated	6	22	18	42.5
NV PSM/4	1822	Interpolated	6	22	18	42.5
NV PSM/5	1822	UUT-2	6	22	18	42.5
NOVUS/1822/00	1822	Interpolated	6	22	18	68
NOVUS/1822/01	1822	Interpolated	6	22	18	68
NOVUS/1822/02	1822	Interpolated	6	22	18	68
NOVUS/1822/03	1822	Interpolated	6	22	18	68
NOVUS/3624/00	3624	Interpolated	6	24	36	68
NOVUS/3624/01	3624	Interpolated	6	24	36	68
NOVUS/3624/02	3624	Interpolated	6	24	36	68
NOVUS/3624/03	3624	Interpolated	6	24	36	68
NOVUS/3624/04	3624	Interpolated	6	24	36	68
NOVUS/3624/05	3624	Interpolated	6	24	36	68
NOVUS/3624/06	3624	Interpolated	6	24	36	68
NOVUS/3624/07	3624	Interpolated	6	24	36	68
NOVUS/3624/08	3624	UUT-3	6	24	36	68
WOC-8500	3624	UUT-4	6	24	36	70.5
EV-32	1822	Interpolated	6	22	18	72.5
EV-64	1822	Interpolated	6	22	18	72.5
EV-32 W/SMC	1822	Interpolated	6	22	18	72.5
EV-64 W/SMC	1822	Interpolated	6	22	18	72.5
EV-96	3624	Interpolated	6	24	36	72.5
EV-128	3624	Interpolated	6	24	36	72.5
EV-96 W/SMC	3624	Interpolated	6	24	36	72.5
EV-128 W/SMC	3624	UUT-5	6	24	36	72.5





#### Table 2. Certified Sub-Component List

Control Box	Control Box										
Part Number	Weight (lb)	Size	Manufacturer	Material	Interpolated / Included With Test						
1212	10lbs	12" x 12" x 6"	Hoffman	16 Ga Cold Rolled Stainless Steel	UUT-1						
1822	33lbs	18" x 22" x 6"	States Electric	16 Ga Cold Rolled Stainless Steel	UUT-2						
3624	63lbs	36" x 24" x 6"	States Electric	14 Ga Cold Rolled Stainless Steel	UUT-3, UUT-4, UUT-5						

Part Number	Weight (lb)	Cabinet	Manufacturer	Material	Interpolated / Included With Test
Jumper Wire	2lbs	1212	West-Com	FR4 Printed Circuit Board	UUT-1
30123024	1lbs	1822	West-Com	FR4 Printed Circuit Board	UUT-2
40118001	1lbs	1822 & 3624	West-Com	FR4 Printed Circuit Board	UUT-3
30123029	1lbs	1822 & 3624	West-Com	FR4 Printed Circuit Board	UUT-3
30118143	1lbs	1822 & 3624	West-Com	FR4 Printed Circuit Board	UUT-3
30118112	2lbs	1822 & 3624	West-Com	FR4 Printed Circuit Board	UUT-3
20121018	1lbs	1822 & 3624	West-Com	FR4 Printed Circuit Board	UUT-3
30118013	2lbs	3624	West-Com	FR4 Printed Circuit Board	UUT-4
30123030	2lbs	3624	West-Com	FR4 Printed Circuit Board	UUT-4
30118006	1lbs	3624	West-Com	FR4 Printed Circuit Board	UUT-4
30118107	1lbs	3624	West-Com	FR4 Printed Circuit Board	UUT-4
30118023	1lbs	3624	West-Com	FR4 Printed Circuit Board	UUT-4
30118008	1lbs	3624	West-Com	FR4 Printed Circuit Board	UUT-4
30118004	1lbs	3624	West-Com	FR4 Printed Circuit Board	UUT-4
30118003	1lbs	3624	West-Com	FR4 Printed Circuit Board	UUT-4
30118007	1lbs	3624	West-Com	FR4 Printed Circuit Board	UUT-4
30118085	1lbs	1822 & 3624	West-Com	FR4 Printed Circuit Board	UUT-5
30018144	1lbs	1822 & 3624	West-Com	FR4 Printed Circuit Board	UUT-5
30118144	1lbs	1822 & 3624	West-Com	FR4 Printed Circuit Board	UUT-5





#### **UUT-1 Test Summary**

Testing Lab: ANCO Engineers


Testing Report: 3308.01
Testing Unit Num: I-Dome HRM


Model Number	Operating Weight (lbs)	Mounting	Excitation Direction		Frequency* (Hz)	Length (in)	Width (in)	Height (in)	
		Wall	Х	Front - Back	NA				
I-Dome HRM	15 Mount				Υ	Side - Side	NA	6.25	12.25
		Mounted	Z	Vertical	NA				


<sup>\*</sup> Frequencies are for units prior to ICC ES AC-156 testing.

		Seismic Para	meters						
Attachment Method	4 - #14 Sheet Metal Screws	Building	Test Criteria	(2)	z/h	Horizontal		Vert	ical
		Code		S <sub>DS</sub> (g)	2/11	$A_{FLX-H}$	$A_{RIG-H}$	$A_{FLX-V}$	$\mathbf{A}_{RIG-V}$
		CBC 2016	AC 156	1.54	1.0	2.46	1.85	1.64	1.23












Figure 1.1: I-Dome HRM

Figure 1.2: Location of Origin / Mounting Locations

Notes: The UUTs were full of contents during the test.

Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

#### **UUT-1 Summary Tested Sub-Component**

Subcomponent	Part Number	Manufacturer
Module	Jumper Wire	West-Com
Control Box	1212	Hoffman





#### **UUT-2 Test Summary**

Testing Lab: ANCO Engineers

 Testing Report:
 3308.01

 Testing Unit Num:
 NV PSM/5

Model Number	Operating Weight (lbs)	Mounting		xcitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)			
		\\/all	Х	Front - Back	NA						
NV PSM/5	42.5	42.5	42.5	Wall Mounted		Υ	Side - Side	NA	6.25	21.5	18
		Modrited	Z	Vertical	NA						

\* Frequencies are for units prior to ICC ES AC-156 testing.

		Seismic Para	meters						
Attachment Method	4 - #14 Sheet Metal Screws	Building	Test Criteria	e (a)	z/h	Horiz	Horizontal		tical
		Code	rest Criteria	S <sub>DS</sub> (g)	2/11	$A_{FLX-H}$	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	$A_{RIG-V}$
		CBC 2016	AC 156	1.54	1.0	2.46	1.85	1.64	1.23






Figure 2.1: NV PSM/5

Figure 2.2: Location of Origin / Mounting Locations

Notes: The UUTs were full of contents during the test.

Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

#### **UUT-2 Summary Tested Sub-Component**

Subcomponent	Part Number	Manufacturer
Module	30123024	West-Com
Control Box	1822	States Electric





#### **UUT-3 Test Summary**

Testing Lab: **ANCO Engineers** 

3308.01

Testing Report: Testing Unit Num: NOVUS/3624/08

Model Number	Operating Weight (lbs)	Mounting		xcitation Direction	Frequency* (Hz)	Length (in)	Width (in)	Height (in)
		Wall	Х	Front - Back	NA			
NOVUS/3624/08	NOVUS/3624/08   68	Mounted	Υ	Side - Side	NA	6.5	24	36
		Mounted	Z	Vertical	NA			

\* Frequencies are for units prior to ICC ES AC-156 testing.

	Seismic Parameters								
Attachment Method	4 - #14 Sheet Metal Screws	Building	Test Criteria	e (a)	z/h	Horiz	ontal	Vert	tical
		Code	rest Criteria	S <sub>DS</sub> (g)	2/11	$A_{FLX-H}$	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	$A_{RIG-V}$
		CBC 2016	AC 156	1.54	1.0	2.46	1.85	1.64	1.23




Figure 3.1: NOVUS/3624/08

Figure 3.2: Location of Origin / Mounting Locations

Notes: The UUTs were full of contents during the test.

Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

#### **UUT-3 Summary Tested Sub-Component**

Subcomponent	Part Number	Manufacturer
Module	40118001	West-Com
Module	30123029	West-Com
Module	30118143	West-Com
Module	30118112	West-Com
Module	20121018	West-Com
Control Box	3624	States Electric





#### **UUT-4 Test Summary**

Testing Lab: ANCO Engineers

 Testing Report:
 3308.01

 Testing Unit Num:
 WOC-8500

Model Number	Operating Weight (lbs)	Mounting	Excitation Direction		Frequency* (Hz)	Length (in)	Width (in)	Height (in)
		Wall	Х	Front - Back	NA			
WOC-8500	70.5	Mounted	Υ	Side - Side	NA	6.5	24	36
		Mounted	Z	Vertical	NA			

\* Frequencies are for units prior to ICC ES AC-156 testing.

	Seismic Parameters								
Attachment Method	4 - #14 Sheet Metal Screws	Building	Test Criteria	e (a)	z/h	Horiz	ontal	Vert	tical
		Code	rest Criteria	S <sub>DS</sub> (g)	2/11	$A_{FLX-H}$	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	$A_{RIG-V}$
		CBC 2016	AC 156	1.54	1.0	2.46	1.85	1.64	1.23






Figure 4.1: WOC-8500

Figure 4.2: Location of Origin / Mounting Locations

Notes: The UUTs were full of contents during the test.

Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

#### **UUT-4 Summary Tested Sub-Component**

Subcomponent	Part Number	Manufacturer
Module	30118013	West-Com
Module	30123030	West-Com
Module	30118006	West-Com
Module	30118107	West-Com
Module	30118023	West-Com
Module	30118008	West-Com
Module	30118004	West-Com
Module	30118003	West-Com
Module	30118007	West-Com
Control Box	3624	States Electric





#### **UUT-5 Test Summary**

Testing Lab: ANCO Engineers

 Testing Report:
 3308.01

 Testing Unit Num:
 EV-128W/SMC

Model Number	Operating Weight (lbs)	Mounting	Excitation Direction		Frequency* (Hz)	Length (in) Widt		Height (in)
		Wall	Х	Front - Back	NA			
EV-128W/SMC	72.5	Mounted	Υ	Side - Side	NA	6.5	24	36
		Mounted	Z	Vertical	NA			

<sup>\*</sup> Frequencies are for units prior to ICC ES AC-156 testing.

	Seismic Parameters								
Attachment Method	4 - #14 Sheet Metal Screws	Building	Test Criteria	e (a)	z/h	Horiz	ontal	Vert	tical
		Code	rest Criteria	S <sub>DS</sub> (g)	2/11	$A_{FLX-H}$	A <sub>RIG-H</sub>	A <sub>FLX-V</sub>	$A_{RIG-V}$
		CBC 2016	AC 156	1.54	1.0	2.46	1.85	1.64	1.23






Figure 5.1: EV-128W/SMC

Figure 5.2: Location of Origin / Mounting Locations

Notes: The UUTs were full of contents during the test.

Unit maintained structural integrity and remained functional per manufacture requirements after shake table test

#### **UUT-5 Summary Tested Sub-Component**

Subcomponent	Part Number	Manufacturer
Module	30118085	West-Com
Module	30018144	West-Com
Module	30118144	West-Com
Control Box	3624	States Electric