



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY

APPLICATION #: OSP – 0139-10

**OSHPD Special Seismic Certification Preapproval (OSP)**

Type:  New  Renewal

**Manufacturer Information**

Manufacturer: H.R. Kirkland Co., Inc.

Manufacturer's Technical Representative: Tricia Kirkland

Mailing Address: 4935 Allison Street, #13, Arvada, CO 80002

Telephone: 800.247.2303 Email: tricia@hrkirkland.com

**Product Information**

Product Name: Graphic Annunciator Panels

Product Type: Graphic Annunciator Panels

Product Model Number: See Attachment A  
(List all unique product identification numbers and/or part numbers)

General Description: Fire alarm annunciator panels with graphic display, switches, and LEDs.

Mounting Description: Rigidly mounted to wall

**Applicant Information**

Applicant Company Name: TRU Compliance, LLC

Contact Person: Derrick A. Watkins, S.E.

Mailing Address: 960 SW Disk Dr., Suite 104, Bend, OR 97702


Telephone: 844.878.0200 Email: dwatkins@trucompliance.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant: *Derrick A. Watkins* Date: 11/28/2016

Title: Executive Vice President Company Name: TRU Compliance, LLC

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: TRU Compliance, LLC

Name: Derrick A. Watkins, S.E. California License Number: S5257

Mailing Address: 960 SW Disk Dr., Suite 104, Bend, OR 97702

Telephone: 844.878.0200 Email: dwatkins@trucompliance.com

**Supports and Attachments Preapproval**

- Supports and attachments are preapproved under OPM- \_\_\_\_\_  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- Supports and attachments are not preapproved

**Certification Method**

- Testing in accordance with:  ICC-ES AC156
- Other (Please Specify): \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_


**Testing Laboratory**

Company Name: ANCO Engineers, Inc.

Contact Name: Paul Ibanez

Mailing Address: 1965-A 33<sup>rd</sup> Street, Boulder, CO 80301

Telephone: 303.443.7580 x239 Email: paul@ancoengineers.com





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION**

**Seismic Parameters**

Design in accordance with ASCE 7-10 Chapter 13:  Yes  No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.7

$S_{DS}$  (Design spectral response acceleration at short period, g) = 2.28

$a_p$  (In-structure equipment or component amplification factor) = 2.5

$R_p$  (Equipment or component response modification factor) = 6.0

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height factor ratio) = 1.0

Equipment or Component Natural Frequencies (Hz) = See Attachment A

Overall dimensions and weight (or range thereof) = See Attachment A

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15:  Yes  No

Design Basis of Equipment or Components ( $V/W$ ) = \_\_\_\_\_

$S_{DS}$  (Design spectral response acceleration at short period, g) = \_\_\_\_\_

$S_{D1}$  (Design spectral response acceleration at 1 second period, g) = \_\_\_\_\_

$R$  (Response modification coefficient) = \_\_\_\_\_

$\Omega_0$  (System overstrength factor) = \_\_\_\_\_

$C_d$  (Deflection amplification factor) = \_\_\_\_\_

$I_p$  (Importance factor) = 1.5

Height to Center of Gravity above base = \_\_\_\_\_

Equipment or Component Natural Frequencies (Hz) = \_\_\_\_\_

Overall dimensions and weight (or range thereof) = \_\_\_\_\_

Tank(s) designed in accordance with ASME BPVC, 2015:  Yes  No

**List of Attachments Supporting Special Seismic Certification**

Test Report(s)  Drawings  Calculations  Manufacturer's Catalog

Other(s) (Please Specify): Attachment A

**OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022**

Signature:  Date: 12/28/2016


Print Name: M. R. Karim Title: SHFR

Special Seismic Certification Valid Up to :  $S_{DS}$  (g) = 2.28  $z/h$  = 1.0

Condition of Approval (if applicable): \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



# SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

16052-CR-001, rev. 0



<b>Manufacturer:</b> H.R. Kirkland Co., Inc.	<b>TABLE 1</b>
<b>Model Line:</b> Graphic Annunciator Panels	

**Certified Product Construction Summary:**  
Carbon steel "Backbox" enclosure and door frame; NVGR Extrusion door mounting bracket. The addition of "-L" to the model number indicates a unit which has the door hinged on the long side of the panel as opposed to the short side.

**Certified Options Summary:**  
Surface or semi-flush wall mounted; Backplane mounting panel on standoffs in Backbox for mounting drivers; G10 fiberglass electrical insulation on door panel. See table 2 for a listing of all other certified subcomponents and options.

**Mounting Configuration:**  
Wall mounted - rigid  
Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

**Building Code:** CBC 2016      **Seismic Certification Limits:**     $S_{DS} = 2.28 g$      $z/h = 1.0$        $I_p = 1.5$

Model Line	Model	Dimensions (in)			Weight (lb)	Notes	UUT
		Depth	Width	Height			
Graphic Annunciator Panels	RSE-L-GR-GP4	5	24	30	53		Interp.
	RSE-GR-GP4	5	30	24	53		2
	RSF-L-GR-GP4	5	30	41.6	94.5		Interp.
	RSF-GR-GP4	5	41.6	30	94.5		1
	RSG-L-GR-GP4	5	41	53	165.5		Interp.
	RSG-GR-GP4	5	53	41	165.5		3

# SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

16052-CR-001, rev. 0



<b>Manufacturer:</b> H.R. Kirkland Co., Inc.	<b>Table Description:</b> Electrical Components	<b>TABLE 2</b>
<b>Model Line:</b> Graphic Annunciator Panels		

**Building Code:** CBC 2016      **Seismic Certification Limits:**  $S_{DS} = 2.28 g$   $z/h = 1.0$        $I_p = 1.5$

Component Type	Manufacturer	Model	Description	Notes	UUT
Switches	C&K Rotary	ES1054	Switch	UUT1: qty (3); UUT2: qty (2); UUT: qty (3)	1,2,3
	Chicago Lock	ES1004	Switch		1,2,3
	SQ	ES4001	Switch		1,2,3
		ES4000	Switch	UUT1: qty (3); UUT2: qty (2); UUT: qty (3)	1,2,3
		ES3003	Switch		1,2,3
	Toggles	ES2001	Switch	UUT1: qty (4); UUT2: qty (4); UUT: qty (4)	1,2,3
	C&K Key	ES1061	Switch		1,2,3
LEDs	King Bright	5mm Super Bright	Standard LED Red/Green/Yellow/White	UUT1: qty (34); UUT2: qty (26); UUT: qty (34)	1,2,3
Relays	Panasonic	ER1007	Lampstest Relay		1,2,3
		ER1012	Lampstest Relay		1,2,3
Drivers	EST	3-ANNCPU	Driver		1,2,3
		3-EVPWRA	Driver		1,2,3
		3-EVDVRA	Driver		1,2,3
	Simplex Grinnell	4100-7401	Driver		1,2
		4100-7402	Driver		1,2
		4100-7403	Driver		1,2
	Notifier	LDM-32	Driver		1,2,3
		LDM-E32	Driver		1,2,3
		SCS-8L	Driver		1,2,3
		SCE-8L	Driver		1,2,3
	Siemens	XLS-OCM-16	Driver		1,2,3
		XLS-SIM-16	Driver		1,2,3
	Hardwired		EP-1012-8	Driver	

# UNIT UNDER TEST (UUT) SUMMARY SHEET

16052-CR-001, rev. 0



<b>Manufacturer:</b> H.R. Kirkland Co., Inc.	<b>UUT 1</b>
<b>Model Line:</b> Graphic Annunciator Panels	
<b>Model Number:</b> RSF-GR-GP4 <b>Serial Number:</b> N/A	


**Product Construction Summary:**  
Annunciator Back box with frame door (hinged on short side) and GP-4 graphic annunciator panel installed in door frame.

**Options/Subcomponent Summary:**  
See Table 2 for a complete listing of included subcomponents.

UUT Properties						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
94.5	5	41.6	30	N/A	N/A	N/A

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>p</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2016	ICC-ES AC156	2.28	1.0	1.5	3.65	2.74	2.43	1.82	

**Test Mounting Details:**



Rigid wall mounted using (4) 1/4" bolts into spring nuts in strut channel.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

16052-CR-001, rev. 0



<b>Manufacturer:</b> H.R. Kirkland Co., Inc.	<b>UUT 2</b>
<b>Model Line:</b> Graphic Annunciator Panels	
<b>Model Number:</b> RSE-GR-GP4 <b>Serial Number:</b> N/A	



**Product Construction Summary:**  
Annunciator Back box with frame door (hinged on short side) and GP-4 graphic annunciator panel installed in door frame.

**Options/Subcomponent Summary:**  
See Table 2 for a complete listing of included subcomponents.

UUT Properties						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
53	5	30	24	N/A	N/A	N/A

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2016	ICC-ES AC156	2.28	1.0	1.5	3.65	2.74	2.43	1.82	

**Test Mounting Details:**



Rigid wall mounted using (4) 1/4" bolts into spring nuts in strut channel.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.

# UNIT UNDER TEST (UUT) SUMMARY SHEET

16052-CR-001, rev. 0



<b>Manufacturer:</b> H.R. Kirkland Co., Inc.	<b>UUT 3</b>
<b>Model Line:</b> Graphic Annunciator Panels	
<b>Model Number:</b> RSG-GR-GP4 <b>Serial Number:</b> N/A	



**Product Construction Summary:**  
Annunciator Back box with frame door (hinged on short side) and GP-4 graphic annunciator panel installed in door frame.

**Options/Subcomponent Summary:**  
See Table 2 for a complete listing of included subcomponents.

UUT Properties						
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
165.5	5	53	41	N/A	N/A	N/A

UUT Highest Passed Seismic Run Information									
Building Code	Test Criteria	S <sub>DS</sub> (g)	z/h	I <sub>P</sub>	A <sub>FLX-H</sub> (g)	A <sub>RIG-H</sub> (g)	A <sub>FLX-V</sub> (g)	A <sub>RIG-V</sub> (g)	
CBC 2016	ICC-ES AC156	2.28	1.0	1.5	3.65	2.74	2.43	1.82	

**Test Mounting Details:**



Rigid wall mounted using (4) 1/4" bolts into spring nuts in strut channel.  
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.  
Contents were included in testing per operating conditions.