APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP) APPLICATION #:** OSP - 0181 - 10 **OSHPD Special Seismic Certification Preapproval (OSP) Manufacturer Information** Manufacturer: AAON, Inc. Manufacturer's Technical Representative: James Velde Mailing Address: 203 Gum Springs Road, Longview, TX 75602 Telephone: 903.247.9263 Email: jvelde@aaon.com **Product Information** Product Name: CB/CC Condensing Units Product Type: Condensers Product Model Number: Varies, see attachment. (List all unique product identification numbers and/or part numbers) General Description: Galvanized steel panel cabinets w/internal & external components. Seismic enhancements made to test units to address anomalies observed during testing shall be incorporated into production units. Mounting Description: Rigid base mounted. **Applicant Information** Applicant Company Name: Structural Integrity Associates, Inc. Contact Person: Matthew J. Tobolski, PhD, SE Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138 Telephone: 541.205.4064 Email: mtobolski@structint.com I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 7/19/2017 Title: Executive Advisor Company Name: Structural Integrity Associates, Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs'





Page 1 of 3

OFFICE USE ONLY

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: Structural Integrity Associates, Inc.
Name: Matthew J. Tobolski, PhD, SE California License Number: S5648
Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138
Telephone: 541.205.4064 Email: mtobolski@structint.com
Supports and Attachments Preapproval
 Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required) Supports and attachments are not preapproved
Certification Method
 ☐ Testing in accordance with: ☐ Other (Please Specify):
Testing Laboratory
Company Name: Clark Testing
Contact Name: Robert Francis
Mailing Address: 1801 Route 51, Jefferson Hills, PA 15025
Telephone: 412.387.1001 Email: <u>rfrancis@clarktesting.com</u>



Page 2 of 13



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes □ No
Design Basis of Equipment or Components (F _p /W _p) = 1.44
S _{DS} (Design spectral response acceleration at short period, g) = 2.00
a _p (In-structure equipment or component amplification factor) = 1.0
R _p (Equipment or component response modification factor) = 2.5
Ω_0 (System overstrength factor) = 2.0
I _P (Importance factor) = 1.5
z/h (Height factor ratio) = 1
Equipment or Component Natural Frequencies (Hz) = See Attachment
Overall dimensions and weight (or range thereof) = See Attachment
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No
Design Basis of Equipment or Components (V/W) =
S _{DS} (Design spectral response acceleration at short period, g) =
S _{D1} (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) =
Ω_0 (System overstrength factor) =
C _d (Deflection amplification factor) =
I _p (Importance factor) = 1.5
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No
List of Attachments Supporting Special Seismic Certification
☐ Test Report(s) ☐ Drawings ☐ Calculations ☐ Manufacturer's Catalog
Other(s) (Please Specify):
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
1// 1 00
Signature: Date: September 15, 2017
Print Name: Timothy J. Piland Title: SSE
Special Seismic Certification Valid Up to : $S_{DS}(g) = 2.00$ $z/h = 1$
Condition of Approval (if applicable):

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





Page 3 of 3

TRU PROJECT NO. 1700667



Manufacturer:
Model Line:

AAON Coil Products, Inc.

CB/CC Packaged Condensing Units

TABLE 1

Certified Product Construction Summary:

20 ga Carbon steel panel construction

Certified Options Summary:

Interior corrosion protection, Single or Three phase 208, 230, or 460V system.

Mounting Configuration:

Base mounted - rigid

Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \text{ g}$ z/h=1.0 $I_P = 1.5$

Model Line	Model	Diı	mensions	(in)	Weight	Notes	UUT
Model Line	Model	Depth	Width	Height	(lb)	notes	001
	CB-B-024	36.3	31.0	36.7	237		Interp.
СВ	CB-B-036	36.3	31.0	36.7	237		Interp.
СВ	CB-B-048	36.3	37.0	40.5	260		Interp.
	CB-B-060	36.3	37.0	40.5	281		Interp.
	CC-B-002	20.2	50.1	38.6	237		9
СС	CC-B-003	20.2	50.1	38.6	237		Interp.
CC	CC-B-004	20.2	50.1	38.6	260		Interp.
	CC-B-005	20.2	50.1	38.6	281		10

TRU PROJECT NO. 1700667



Manufacturer: AAON Coil Products, Inc.

Table Description: Compressors

CB/CC Packaged Condensing Units

TABLE 2

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \, \text{g}$ z/h=1.0 $I_P = 1.5$

Component		Di	mension (in)	Weight		
(manufacturer)	Model	Depth	Width	Height	(lb)	Notes	וטט
	ZPS20K4E	9.5	9.5	16	67		9
	ZPS30K4E	9.5	9.5	16	68.2		Inter
Compressors	ZPD34K5E	9.6	9.6	17.7	68.2		Inter
(Copeland)	ZPS40K4E	9.5	9.5	16	68.2		Inter
	ZPD42K5E	9.3	9.3	18.4	68.2		Inter
	ZPS51K4E	9.6	9.6	16.9	76.6		10

TRU PROJECT NO. 1700667



Manufacturer: AAON Coil Products, Inc.

Table Description: Fan motors - mounted to fan assembly

CB/CC Packaged Condensing Units

TABLE 3

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \text{ g}$ z/h=1.0 $I_P = 1.5$

bunuing code. CDC 20		Seising Certification Limits. 3 ps = 2.0 g 2/n=1.0									
Component Type	Manufacturer	Model	Description	Notes	UUT						
Fan Motors	GE	48	1/2 HP, 208/230-460V, 17 lbs.	UUT10: 460V; UUT9: 208/230V	9,10						

TRU PROJECT NO. 1700667



Manufacturer: AAON Coil Products, Inc.

Table Description: Fans

TABLE 4

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \text{ g}$ z/h=1.0 $I_P = 1.5$

Model Line		Di	mension (in)	Weight			
(Manufacturer)	Model	Diam.	Blades	Width	(lb)	Material	Notes	UUT
Fama	T12E07A	22	3	8	2.1	Carbon steel		9
Fans (LAU)	6088190	22	3	8	2.1	Carbon steel		Interp.
(LAU)	T5082630	26	3	8	2.3	Carbon steel		10

TRU PROJECT NO. 1700667



Manufacturer: AAON Coil Products, Inc.

Table Description: Microchannel Coils

CB/CC Packaged Condensing Units

TABLE 5

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \text{ g}$ z/h=1.0 $I_P = 1.5$

Dunaning Code. CDC 20		Seisinc Cercification Limits. Sps = 2.0 g 2/H=1.0							
Model Line	Model		mension (Weight	Material	Notes	UUT	
(Manufacturer)		Depth	Width	Height	(lb)				
Microchannel (Delphi)	Custom Coils		33.8	43	30	Aluminum	2-5 ton CC A/C	10	

TRU PROJECT NO. 1700667



Manufacturer: AAON Coil Products, Inc.

Table Description: Tube and Fin Coils

CB/CC Packaged Condensing Units

TABLE 6

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \text{ g}$ z/h=1.0 $I_P = 1.5$

Model Line	Model	Di	mension (in)	Weight	Material	Notes	UUT
(Manufacturer)	моаеι	Depth	Width	Height	(lb)	material	Notes	001
Tube and Fin Coils (AAON, INC.)	Custom Coils	3 row	43	34	67	Cu tube, Al fin, CS Casing		9

Tube Wall Thickness: .012" Fin Thickness: .0060" aluminum; Fins per Inch: 22

TRU PROJECT NO. 1700667



Manufacturer:
Model Line:AAON Coil Products, Inc.Table Description: SensorsTABLE 7

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \text{ g}$ z/h=1.0 $I_P = 1.5$

Madallina		Dimension (in)			Waisht		
Model Line (Manufacturer)	Model	Depth	Width	Height	Weight (lb)	Notes	UU
Johnson Controls	P352PN-4C	2.4	2.4	5	1		9-1

TRU PROJECT NO. 1700667



Manufacturer: AAON Coil Products, Inc.

Table Description: Expansion Valves

TABLE 8

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \, \text{g}$ z/h=1.0 $I_P = 1.5$

Model Line		Di	mension (in)	Weight		
(Manufacturer)	Model	Depth	Width	Height	(lb)	Notes	רטט
	CBBIZE-2	1.5	1.9	2.9	0.9		9
Charlan	CBBIZE-3	1.5	1.9	2.9	0.9		Inter
Sporlan	CBBIZE-4	1.5	1.9	2.9	1.2		Inter
	CBBIZE-5	1.5	1.9	2.9	1.2		10

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 1700667



UUT9

Manufacturer: AAON Coil Products, Inc.

Model Line: CB/CC Packaged Condensing Units

Model Number: CC-B-002 (CC-B-002-1-B-1:BG00000) Serial Number: N/A

Product Construction Summary:

Painted carbon steel enclosure

Options/Subcomponent Summary:


Compressor: Copeland ZPS20K4E; Fan Motor: GE 1/2HP; Fan: LAU T12E07A; Coil: 3 Row Tube and Fin;

Sensors: JCI P352PN-4C

Internal Components: 208/230V

UUT Properties												
Weight		Dimension (in)	Lowest Natural Frequency (Hz)									
(lb)	Depth	Width	Front	-Back	Side	-Side	Ver	tical				
325	20.2	50.1	50.1 38.6				11.8		> 33.3			
		UUT Highest	Passed Se	eismic Rui	n Informa	ation						
Buildi	ing Code	Test Criter	Test Criteria		z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)		
CBC 2016		ICC-ES AC156		2.0	1.0	1.5	3.2	2.4	1.33	0.53		

Test Mounting Details:



Unit was rigid base mounted to the shake table using (4) 2"x2"x 8"x1/4" carbon steel angles. Each angle used (4) #14 x 1-1/2" zip screws to attach to the unit and (1) 1/2"-13 bolt (Grade 5) to anchor to the shake table.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET

TRU PROJECT NO. 1700667



UUT 10

Manufacturer: AAON Coil Products, Inc.

Model Line: CB/CC Packaged Condensing Units

Model Number: CC-B-005 (CC-B-005-3-B-1:0DB000X) Serial Number: N/A

Product Construction Summary:

Painted carbon steel enclosure

Options/Subcomponent Summary:

Compressor: Copeland ZPS51K4E; Fan Motor: GE 1/2HP; Fan: LAU 6123840001; Coil: Delphi Microchannel;


Sensors: JCI P352PN-4C Internal Components: 460V


	UUT Properties										
Weight		Dimension (in)		Lowest Natural Frequency (Hz)							
(lb)	Depth	Width	Height	Front-Back	Side-Side	Vertical					
330	20.2	50.1	38.6	30.2	11.3	> 33.3					

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2016	ICC-ES AC156	2.0	1.0	1.5	3.2	2.4	1.33	0.53

Test Mounting Details:





Unit was rigid base mounted to the shake table using (4) 2"x2"x 8"x1/4" carbon steel angles. Each angle used (4) #14 x 1-1/2" zip screws to attach to the unit and (1) 1/2"-13 bolt (Grade 5) to anchor to the shake table.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.