



**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

**APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)**

OFFICE USE ONLY	
APPLICATION #:	OSP – 0192-10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: New Renewal

Manufacturer Information

Manufacturer: IEA, LLC, an Engendren Corporation Subsidiary

Manufacturer's Technical Representative: Greg Guthrie

Mailing Address: 9625 55th Street, Kenosha, WI 53144

Telephone: (262) 942-1414 Email: gguthrie@iearad.com

Product Information

Product Name: HCR, ECC, and EC Radiators

Product Type: Radiators

Product Model Number: See Attached OSP Product Summary

(List all unique product identification numbers and/or part numbers)

General Description: HCR units are modular radiators consisting of a varying number of individual core and fan sections, and the ECC units and EC units are engine coolers with fans.

Mounting Description: HCR units are rigidly mounted to floor and ECC & EC units are floor mounted with external isolators and snubbers.

Applicant Information


Applicant Company Name: The VMC Group

Contact Person: John Giuliano


Mailing Address: 113 Main Street, Bloomingdale, NJ 07403

Telephone: (973) 838-1780 Email: john.giuliano@thevmcgroup.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant:  Date: 1/3/17

Title: President Company Name: The VMC Group





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: The VMC Group

Name: Ken Tarlow California License Number: SE2851

Mailing Address: 980 9th Street, Sacramento, CA 95814

Telephone: (973) 838-1780 Email: Ken.Tarlow@thvmcgroup.com

Supports and Attachments Preapproval

Supports and attachments are preapproved under OPM- _____
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)

Supports and attachments are not preapproved

Certification Method

Testing in accordance with: ICC-ES AC156

Other (Please Specify): _____

Testing Laboratory

Company Name: Dynamic Certification Laboratories, LLC


Contact Name: Kelly Laplace, Quality Manager

Mailing Address: 1315 Greg Street, Suite 109, Sparks, NV 89431

Telephone: (775) 358-5085 Email: Kelly@shaketest.com

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY
OSH-FD-759 (REV 12/16/15)





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: Yes No

Design Basis of Equipment or Components (F_p/W_p) = 1.39 (rigid mount), 4.34 (spring isolated)

S_{DS} (Design spectral response acceleration at short period, g) = 1.93

a_p (In-structure equipment or component amplification factor) = 1.0 (rigid mount), 2.5 (spring isolated)

R_p (Equipment or component response modification factor) = 2.5 (rigid mount), 2.0 (spring isolated)

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 1.0

Equipment or Component Natural Frequencies (Hz) = See Attachments

Overall dimensions and weight (or range thereof) = See Attachments

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = _____

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2015: Yes No

List of Attachments Supporting Special Seismic Certification

Test Report(s) Drawings Calculations Manufacturer's Catalog

Other(s) (Please Specify): Previous OSP


OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022

Signature:  Date: 1/31/17

Print Name: M. R. Karim Title: SHFR

Special Seismic Certification Valid Up to : S_{DS} (g) = 1.93 z/h = 1.0

Condition of Approval (if applicable): _____



Manufacturer: IEA

Table 1 - Certified Components

Model	Dimensions (in)			Approx. Weight (lb)	Construction	Mounting	Sds (g), z/h=1	UUT
	Depth	Width	Height					
HCR-Q036	91.75	75.00	125.50	4, 720	Carbon Steel	Rigid floor mounted	1.93	UUT 1
HCR-Q072	163.70	75.00	127.80	6, 155				Interpolated
HCR-Q108	235.70	75.00	127.80	7, 590				Interpolated
HCR-Q058	114.00	90.00	131.75	6, 950				Interpolated
HCRQ116	211.70	90.00	131.75	9, 936		Interpolated		
HCR-Q174	307.75	90.00	131.75	11, 400		UUT 2		
ECC-S072	87.00	118.50	131.75	7, 238		Floor mounted with vibration isolator		UUT 3
EC-100	97.75	124.25	153.00	9, 315				UUT 4

Table 2 - Certified Subcomponents: Motors

Model	HP	Dimensions (in)			Approx. Weight (lb)	Component Mfg.	Casing Material	UUT
		Depth	Width	Height				
EP0154 Type AEHH-8N	15	23.78	13.15	14.84	304	TECO Westinghouse	Cast Iron	UUT 1
EP0204 Type AEHH-8N	20	25.52	13.15	14.84	344			Interpolated
EP0254 Type AEHH-8N	25	26.8	15.04	16.52	429			Interpolated
EP0304 Type AEHH-8N	30	28.3	15.04	16.88	486	US Motors	Cast Iron	UUT 2
U30P2D NEMA Premium		28.25	13.38	13.69	325			UUT 2
W22 - NEMA Premium		27.93	14.17	14.07	450	WEG Electric	UUT 2	

Table 3 - Certified Subcomponents: Fuel Coolers

Model	Dimensions (in)			Approx. Weight (lb)	Component Mfg.	Construction Material	UUT
	Depth	Width	Height				
DH-326-211292	26.75	24.25	1.50	16.00	Thermal Transfer	Copper / Aluminum	UUT 1, UUT 2, UUT 3
DH-326-1-1	25.00	24	1.50	8.00			UUT 4

Table 4 - Certified Subcomponents: Fans

Model	Dimensions		Approx. Weight (lb)	Component Mfg.	Material	UUT
	Diameter (in)					
10000 Class, Series 24SD	60		105	Moore Fan	Aluminum	UUT 1
10000 Class, Series 30SD	84		171			UUT 2, UUT 4
15/10201	84		431	Truflo	Carbon Steel	UUT 3

Table 5 - Certified Subcomponents: Fan Shaft Bearing

Model	Dimensions (in)			Approx. Weight (lb)	Component Mfg.	Casing Material	UUT
	Depth	Width	Height				
5-2000 Series	5.13	5.13	2.97	1.00	Dodge	Cast Iron	UUT 1, UUT 2
2000 Series	6.13	6.13	3.52	1.81			UUT 1, UUT 2
USRBE5000-307	4.47	13.50	7.38	39.0	Seal-Master	Cast Iron	UUT 4

Table 6 - Certified Subcomponents: Idler Sheave Bearing

Model	Dimensions		Approx. Weight (lb)	Component Mfg.	Material	UUT
	Diameter (mm)					
5309-C	1.77		5.00	MRC	52100 Steel	UUT 3
5312-C	2.36		6.28			UUT 4

Table 7 - Certified Subcomponents: Miscellaneous

Model	Dimensions (in)			Approx. Weight (lb)	Component Mfg.	Construction Material	Description	UUT
	Depth	Width	Height					
913-NLU-TD10-T	4.00	1.75	1.75	0.19	Cooper-Standard	Brass	Low Level Alarm Probe	UUT 3
SM6-165-A	2.25	3.25	1.65	0.14	Isolation Dynamics	Stainless Steel	Pipe Isolators	UUT 3
0.0075 AL Fins, 0.625 x 0.20 CU Tubes	15.00	90.00	300.00	2380.00	Super Coils	Copper / Aluminum	Cooling Coil	UUT 1, UUT 2
0.0075 AL Fins, 0.625 x 0.32 CU Tubes	9.50	75.00	85.00	555.00				UUT 1, UUT 2
EL150K1	2.75	4.75	5.00	2.63	Murphy Industries	Cast Iron	Liquid Level	UUT 1, UUT 2

Table 8 - Tested Unit Matrix

Model	Dimensions (in)			Approx. Weight (lb)	Construction	Mounting	Sds (g), z/h=1	UUT
	Depth	Width	Height					
HCR-Q036	91.75	75.00	125.50	4, 720	Carbon Steel	Rigid floor mounted	1.93	UUT 1
HCR-Q174	307.75	90.00	131.75	11, 400				UUT 2
ECC-S072	87.00	118.50	131.75	7, 238		Floor mounted with vibration isolator		UUT 3
EC-100	97.75	124.25	153.00	9, 315				UUT 4



UNIT UNDER TEST (UUT) SUMMARY SHEET

UUT-01

88135-1001

Model Line	Model Number	Manufacturer
HCR Modular Radiators	HCR Q036	IEA, LLC

Product Construction Summary

Fabricated carbon steel structure with aluminum fins, copper tubes, aluminum fans and multi-voltage 15 HP electric motor

Options / Subcomponent Summary

36 square foot Radiator, SR Coils, 6" Flange

UUT Properties

Weight [lb]	Dimensions [in]			Lowest Nat. Freq. [Hz]		
	Length	Width	Height	F-B	S-S	V
4,720	92.0	75.0	125.6	5.0	5.8	23.3

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2016	ICC-ES AC156	2.26	1	1.5	3.2	2.71	1.51	0.6

Test Mounting Details

The unit was mounted to the DCL-provided steel shake table interface frame at four corners through each of the unit's legs using Grade 8, 3/4-inch bolts (four bolts total). The steel interface frame was bolted to the shake table using M12 threaded rod at a spacing of approximately 8-inches on-center.



All units were filled with contents and maintained structural integrity and functionality after shake table test



**UNIT UNDER TEST (UUT)
SUMMARY SHEET**

UUT-02

88135-1001

Model Line	Model Number	Manufacturer
HCR Modular Radiators	HCR Q174	IEA, LLC

Product Construction Summary

Fabricated carbon steel structure with aluminum fins, copper tubes, aluminum fans and multi-voltage 30 HP electric motor

Options / Subcomponent Summary

174 square foot Radiator, SR Coils, 6" Flange

UUT Properties

Weight [lb]	Dimensions [in]			Lowest Nat. Freq. [Hz]		
	Length	Width	Height	F-B	S-S	V
11,400	308.0	90.0	132.0	11.5	8.2	24.8

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2016	ICC-ES AC156	1.93	1.00	1.50	3.09	2.32	1.29	0.52

Test Mounting Details

The unit was mounted to the DCL-provided steel shake table interface frame at twelve points through each of the unit's legs using Grade 8, 3/4-inch bolts (twelve total). The steel interface frame was mounted to the shake table using A490 1 1/2-inch diameter bolts at a spacing of approximately 12-inches on-center.



All units were filled with contents and maintained structural integrity and functionality after shake table test



**UNIT UNDER TEST (UUT)
SUMMARY SHEET**

UUT-03

88135-1001

Model Line	Model Number	Manufacturer
ECC S072 (Stand-Alone Product)	ECC S072	IEA, LLC

Product Construction Summary

Fabricated carbon steel structure with aluminum fins, copper tubes, aluminum fan

Options / Subcomponent Summary

Fuel Cooler, Fan, Fan Shaft Bearing, Idler Sheave Bearing, Low Level Alarm Probe, Pipe Isolators, and Vibration Isolators

UUT Properties

Weight [lb]	Dimensions [in]			Lowest Nat. Freq. [Hz]		
	Length	Width	Height	F-B	S-S	V
7,238	87.0	119.0	132.0	2.5	4.3	7.6

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2016	ICC-ES AC156	1.93	1.00	1.50	3.09	2.32	1.29	0.52

Test Mounting Details

The unit was mounted at the base in six locations to vibration isolators supplied by CalDyne using Grade 8, 3/4-inch bolts. Four of the isolators were CalDyne model RJJEQ A-3040, mounted on the heavy side of the unit; two further from the center of gravity and two at the approximate mid-point of the unit. Two of the isolators were CalDyne model RJJEQ A-2120, mounted on the light side of the unit. The isolators were mounted to steel I-beams using a total of four (4) Grade 8, 5/8-inch bolts per isolator and the I-beams were attached to the shake table using 1 1/2-inch A490 bolts.



All units were filled with contents and maintained structural integrity and functionality after shake table test



**UNIT UNDER TEST (UUT)
SUMMARY SHEET**

UUT-04

88135-1001

Model Line	Model Number	Manufacturer
EC 100 (Stand-Alone Product)	EC 100	IEA, LLC

Product Construction Summary

Fabricated carbon steel structure with aluminum fins, copper tubes, aluminum fan

Options / Subcomponent Summary

Fuel Cooler, Fan, Fan Shaft Bearing, Idler Sheave Bearing, and Vibration Isolators

UUT Properties						
Weight [lb]	Dimensions [in]			Lowest Nat. Freq. [Hz]		
	Length	Width	Height	F-B	S-S	V
9,315	98.0	125.0	153.0	4.3	5.1	13.7

UUT Highest Passed Seismic Run Information								
Building Code	Test Criteria	S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2016	ICC-ES AC156	1.93	1.00	1.50	3.09	2.32	1.29	0.52

Test Mounting Details

The unit was mounted at the base in six locations to vibration isolators supplied by CalDyne using Grade 8, 3/4-inch bolts. Four of the isolators were CalDyne model RJJEQ D-4560, mounted on the heavy side of the unit; two further from the center of gravity and two approximately 1/3 of the distance from the heavy end of the unit. Two of the isolators were CalDyne model RJJEQ D-2403, mounted on the light side of the unit. The isolators were mounted to steel I-beams using a total of four (4) Grade 8, 7/8-inch bolts per isolator and the I-beams were attached to the shake table using 1 1/2-inch A490 bolts.



All units were filled with contents and maintained structural integrity and functionality after shake table test