



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP – 0258 – 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: ☐ New ☒ Renewal

Manufacturer Information

Manufacturer: Myers Power Products, Inc.

Manufacturer's Technical Representative: Bruce Steigerwald

Mailing Address: 44 South Commercial Way, Bethlehem, PA 18017

Telephone: 610.868.3500 Email: bruce.steigerwald@myerspower.com

Product Information

Product Name: Illuminator CIII

Product Type: Lighting Inverter System

Product Model Number: Various (See Attachment)

(List all unique product identification numbers and/or part numbers)

General Description: 3-Phase Emergency Lighting Inverter System. Seismic enhancements made to the test units and modifications required to address the anomalies observed during the tests shall be incorporated into the production units.

Mounting Description: Rigid Floor Mounted

Applicant Information

Applicant Company Name: SEESudio, Inc.

Contact Person: Dan Junker, SE

Mailing Address: 1281 9th Ave. san Diego, CA 92101, Suite 1101


Telephone: 619.606.5058 Email: djunker@seestudioinc.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant:  Date: 04-15-16

Title: Principal Engineer Company Name: SEESudio, Inc.

Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: SEESTudio, Inc.

Name: Dan Junker, SE California License Number: S6178

Mailing Address: 1281 9th Ave. San Diego, CA 92101, Suite 1101

Telephone: 619.606.5058 Email: djunker@seestudioinc.com

Supports and Attachments Preapproval

- ☐ Supports and attachments are preapproved under OPM-
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- ☒ Supports and attachments are not preapproved

Certification Method

- ☒ Testing in accordance with: ☒ ICC-ES AC156
- ☐ Other (Please Specify): _____


Testing Laboratory

Company Name: Clark Dynamic Test Laboratory, Inc.

Contact Name: Robert Francis, General Manager

Mailing Address: 1801 Route 51 Jefferson Hills, PA 15025

Telephone: 412-387-1004 Email: rfrancis@clarktesting.com





OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: ☒ Yes ☐ No

Design Basis of Equipment or Components (F_p/W_p) = 1.80

S_{DS} (Design spectral response acceleration at short period, g) = 2.5

a_p (In-structure equipment or component amplification factor) = 1.0

R_p (Equipment or component response modification factor) = 2.5

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 1.0

Equipment or Component Natural Frequencies (Hz) = See Attachment

Overall dimensions and weight (or range thereof) = See Attachment

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: ☐ Yes ☒ No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = _____

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No

List of Attachments Supporting Special Seismic Certification

☒ Test Report(s) ☐ Drawings ☐ Calculations ☒ Manufacturer's Catalog

☒ Other(s) (Please Specify): SEES Component Certification Summary


OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022

Signature:  Date: August 6, 2016

Print Name: Timothy J. Piland Title: SSE

Special Seismic Certification Valid Up to : S_{DS} (g) = 2.50 z/h = 1

Condition of Approval (if applicable): _____





SPECIAL SEISMIC CERTIFICATION

CERTIFIED COMPONENTS

TABLE **1**

MANUFACTURER: Myers Power Products, Inc.
MODEL LINE: Illuminator Series IC3 Lighting Inverters
TABLE DESCRIPTION: Lighting Inverters

CONSTRUCTION SUMMARY:	CERTIFICATION PARAMETERS:
Powder-coated cold-rolled carbon steel enclosure. Lockable hinged doors. Certified unit construction shall be identical to cabinet construction of UUT's.	Building Code: CBC 2016
OPTIONS SUMMARY:	Component Importance Factor: $I_p = 1.5$
Internal components as detailed in following Certified Sub-Component tables.	S_{DS} at $z/h = 1.0$: $S_{DS} = 2.5g$

MOUNTING SUMMARY:	NOTES:
Rigid floor mounted. Unit anchorage shall be designed on a project specific basis by SEOR. Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.	

Model Line	Model	Max Dimensions (in)			Weight (lb)	Description		UUT
		Depth	Width	Height		kVA	Voltage	
Illuminator Series IC3	1-D-1-S-Cxxx01-S-H	25.0	60.0	47.0	1,633	4	120/208V	
	2-D-1-S-Cxxx01-S-H	25.0	60.0	47.0	1,633	4	277/480V	
	1-D-2-S-Cxxx01-S-H	25.0	60.0	47.0	1,855	6	120/208V	
	2-D-2-S-Cxxx01-S-H	25.0	60.0	47.0	1,855	6	277/480V	
	1-D-3-S-Cxxx01-S-H	25.0	90.0	47.0	2,247	8	120/208V	
	2-D-3-S-Cxxx01-S-H	25.0	90.0	47.0	2,247	8	277/480V	
	1-D-4-S-Cxxx01-S-H	25.0	90.0	47.0	2,835	10	120/208V	
	2-D-4-S-Cxxx01-S-H	25.0	90.0	47.0	2,835	10	277/480V	
	1-D-5-S-Cxxx01-S-H	25.0	90.0	47.0	3,279	12.5	120/208V	
	2-D-5-S-Cxxx01-S-H	25.0	90.0	47.0	3,279	12.5	277/480V	
	1-D-6-S-Cxxx01-S-H	25.0	90.0	47.0	4,063	16.7	120/208V	
	2-D-6-S-Cxxx01-S-H	25.0	90.0	47.0	4,063	16.7	277/480V	1
	1-D-7-S-Cxxx01-S-H	31.0	92.0	72.0	6,390	24	120/208V	
	2-D-7-S-Cxxx01-S-H	31.0	92.0	72.0	6,390	24	277/480V	
	1-D-8-S-Cxxx01-S-H	31.0	140.0	72.0	8,630	33	120/208V	
	2-D-8-S-Cxxx01-S-H	31.0	140.0	72.0	8,630	33	277/480V	
	1-D-9-S-Cxxx01-S-H	31.0	140.0	72.0	10,150	40	120/208V	
	2-D-9-S-Cxxx01-S-H	31.0	140.0	72.0	10,150	40	277/480V	
	1-D-10-S-Cxxx01-S-H	31.0	140.0	72.0	11,980	50	120/208V	
	2-D-10-S-Cxxx01-S-H	31.0	140.0	72.0	11,980	50	277/480V	2



TABLE 2

TABLE DESCRIPTION: Main Transformers

Mounted in component. Certified mounting shall be identical to mounting of sub-component in UUT's.

Page 5 of 12



TABLE 3

NOTES:

Page 6 of 12



TABLE 4

TABLE DESCRIPTION: DC Sub-Assembly

NOTES:

Sub-Assembly Part Number: SA-403002, SA-403007

Document No.: 2016-015-CCS-001.0



TABLE 5

TABLE DESCRIPTION: AC Sub-Assembly

Sub-Assembly Part Number: SA-403003, SA-403006

Page 8 of 12

SPECIAL SEISMIC CERTIFICATION

UNIT UNDER TEST (UUT) DESCRIPTION

UUT **1**

MANUFACTURER: Myers Power Products, Inc.
MODEL LINE: Illuminator Series IC3 Lighting Inverters
MODEL NUMBER: D-6-S

CONSTRUCTION SUMMARY:

Powder-coated cold-rolled carbon steel enclosure. Lockable hinged doors.

OPTIONS SUMMARY:

Myers XF-FM113806 main transformer, Little Fuse NLN fuses, Marathon F60A1B fuse block, East Penn Mfg. 12AVR100-3ET batteries, Leoch FT12-100 batteries, Powerex NF Series IGBT, Precision Graphics 403164 IGBT PCB, Cornell Dubilier type DCMC DC capacitor, Richardson RFPD 96-0117-203135 heatsink, Mechatronics UF12A12 fan, Filtran Limited 113141 current transformer, Marathon RF100A1B fuse block, LEM HAS 100-S current sensor, Precision Graphics 403569 control PCB, Infineon G2B17 SCR, AZ Circuits 403764 SCR PCB, Bussman FWH SCR fuses, Richardson RFPD 202867 heatsink, Little Fuse V321DA40 varistor, Myers 113751 power supply transformer, Kraus & Naimer C80-6US6900-600E bypass switch, Square D FAL circuit breaker

TEST PARAMETERS:

Building Code: CBC 2016

Component Importance Factor: $I_p = 1.5$

Test Criteria: AC-156

MOUNTING SUMMARY:

Rigid floor mount. Unit mounted to shake table using six (6) grade 5 5/8-11 bolts.

NOTES:

Contents were included in testing per operating conditions.

UUT IMAGE



UUT PROPERTIES

Dimensions (in)			Weight (lb)	First Natural Frequency (Hz)		
Depth	Width	Height		F-B	S-S	Vert
25.0	90.0	47.0	4,015	23.1	24.5	N/A

UNIT MAINTAINED STRUCTURAL INTEGRITY AND REMAINED OPERATIONAL

PER MANUFACTURER REQUIREMENT WHEN SUBJECTED TO THE FOLLOWING TEST PARAMETERS

S_{Ds} (g)	z/h	A_{FLX-H} (g)	A_{RIG-H} (g)	A_{FLX-V} (g)	A_{RIG-V} (g)
2.5	1.0	4.0	3.0	1.67	0.67




SPECIAL SEISMIC CERTIFICATION

UNIT UNDER TEST (UUT) DESCRIPTION

UUT **1**

MANUFACTURER: Myers Power Products, Inc.
MODEL LINE: Illuminator Series IC3 Lighting Inverters
MODEL NUMBER: D-6-S

SUPPORT AND ATTACHMENT SUMMARY:



SPECIAL SEISMIC CERTIFICATION

UNIT UNDER TEST (UUT) DESCRIPTION

UUT **2**

MANUFACTURER: Myers Power Products, Inc.
MODEL LINE: Illuminator Series IC3 Lighting Inverters
MODEL NUMBER: D-10-S

CONSTRUCTION SUMMARY:

Powder-coated cold-rolled carbon steel enclosure. Lockable hinged doors.

OPTIONS SUMMARY:

Myers XF-FM113808 main transformer, Little Fuse NLN fuses, Marathon F60A1B fuse block, East Penn Mfg. 12AVR100-3ET batteries, Leoch FT12-100 batteries, Powerex NF Series IGBT, Precision Graphics 403164 IGBT PCB, Cornell Dubilier type DCMC DC capacitor, Richardson RFPD 96-0117-203141 heatsink, Mechatronics UF12A12 fan, Filtran Limited 113141 current transformer, Marathon RF100A1B fuse block, LEM HAS 400-S current sensor, Precision Graphics 403569 control PCB, Infineon G2B17 SCR, AZ Circuits 403764 SCR PCB, Bussman FWH SCR fuses, Richardson RFPD 203091 heatsink, Little Fuse V321DA40 varistor, Myers 113751 power supply transformer, Kraus & Naimer C80-6US6900-600E bypass switch, Square D FAL circuit breaker

TEST PARAMETERS:

Building Code: CBC 2016

Component Importance Factor: $I_p = 1.5$

Test Criteria: AC-156

MOUNTING SUMMARY:

Rigid floor mount. Unit mounted to shake table using sixteen (16) grade 5 5/8-11 bolts.

NOTES:

Contents were included in testing per operating conditions.

UUT IMAGE



UUT PROPERTIES

Dimensions (in)			Weight (lb)	First Natural Frequency (Hz)		
Depth	Width	Height		F-B	S-S	Vert
31.0	140.0	72.0	11,398	5.7	7.0	9.9

UNIT MAINTAINED STRUCTURAL INTEGRITY AND REMAINED OPERATIONAL

PER MANUFACTURER REQUIREMENT WHEN SUBJECTED TO THE FOLLOWING TEST PARAMETERS

S_{DS} (g)	z/h	A_{FLX-H} (g)	A_{RIG-H} (g)	A_{FLX-V} (g)	A_{RIG-V} (g)
2.5	1.0	4.0	3.0	1.67	0.67



SPECIAL SEISMIC CERTIFICATION

UNIT UNDER TEST (UUT) DESCRIPTION

UUT **2**

MANUFACTURER: Myers Power Products, Inc.
MODEL LINE: Illuminator Series IC3 Lighting Inverters
MODEL NUMBER: D-10-S

SUPPORT AND ATTACHMENT SUMMARY:

