

OFFICE USE ONLY
APPLICATION #: OSP – 0269-10
ANADA K7C 3P1
②dynamicaqs.com
d combination of medias, bonded together in a e module. <i>Used in rigid base mounted</i>
he tops and bottoms of the stacks were fastened
astened to a vertical support frame on both sides.
NJ 08553
ried@dynamicaqs.com
Planning and Development review fees in
Date: _ Jan 16, 2017
nic Air Quality Solutions

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY

OSH-FD-759 (REV 12/16/15)

-M/M/M

Page 1 of 7

07/02/2017 OSP-0269-10

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)											
Company Name: ARCHES ENGINEERING, LLC.											
Name: RUTH MILLER California License Number: S4657											
Mailing Address: P.O. Box 3852, GRAND JUNCTION, CO 81502											
Telephone: (970) 255-6788 Email: ruth@archesengineering.com											
Supports and Attachments Preapproval											
 Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required) Supports and attachments are not preapproved 											
Certification Method											
 ☐ Testing in accordance with: ☐ Other (Please Specify): 											
Testing Laboratory											
Company Name: VERSATILE MEASURING INSTRUMENTS INC.											
Contact Name: SHERWIN JAMISOLA											
Mailing Address: 165 PONY DRIVE, NEWMARKET, ONTARION L3Y 7B5											
Telephone: (905) 954-0841 Email: sjamisola@amidyne.com											

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 12/16/15)





Page 2 of 3

Seismic Parameters

07/02/2017 OSP-0269-10 Page 2 of 7



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Design in accordance with ASCE 7-10 Chapter 13: ☐ Yes ☐ No
Design Basis of Equipment or Components (F _p /W _p) = 1.88
S _{DS} (Design spectral response acceleration at short period, g) = 2.49
a _p (In-structure equipment or component amplification factor) = 2.5
R _p (Equipment or component response modification factor) = 6.0
Ω_0 (System overstrength factor) = 2.0
I _p (Importance factor) = 1.5
z/h (Height factor ratio) = 1.0
Equipment or Component Natural Frequencies (Hz) = See Attachments
Overall dimensions and weight (or range thereof) = See Attachments
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No
Design Basis of Equipment or Components (V/W) =
S _{DS} (Design spectral response acceleration at short period, g) =
S _{D1} (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) =
Ω_0 (System overstrength factor) =
C _d (Deflection amplification factor) =
I _p (Importance factor) = 1.5
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No
List of Attachments Supporting Special Seismic Certification
☐ Test Report(s) ☐ Drawings ☐ Calculations ☐ Manufacturer's Catalog
☐ Other(s) (Please Specify):
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
Approval (1 of Chice Coc Chily) Approval Expires on December 31, 2022
Signature:
Print Name: M. R. Karim Title: SHFR
Special Seismic Certification Valid Up to : $S_{DS}(g) = 2.49$ $z/h = 1.0$
Condition of Approval (if applicable):

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs" STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 12/16/15)







REI No: R10-09-22F

105 School Creek Trail Luxemburg, WI 54217 Phone: (920)845-1042 Fax: (920)845-1048 www.rice-inc.com

TABLE 1

SEISMICALLY CERTIFIED COMPONENTS

		WEIGHT	DEPTH	WIDTH	HEIGHT	
PRODUCT LINE	MODULE SIZE	(LB)	(IN)	(IN)	(IN)	BASIS
V8 Air Cleaner	1V82612-24-F	21	24	26	12	Interpolated
V8 Air Cleaner	1V82612-29.5-F	26	29.5	26	12	UUT1
V8 Air Cleaner	1V83012-24-F	25	24	30	12	Interpolated
V8 Air Cleaner	1V83012-29.5-F	30	29.5	30	12	Interpolated
V8 Air Cleaner	1V83412-24-F	28	24	34	12	Interpolated
V8 Air Cleaner	1V83412-29.5-F	34	29.5	34	12	Interpolated
V8 Air Cleaner	1V83812-24-F	31	24	38	12	Interpolated
V8 Air Cleaner	1V83812-29.5-F	38	29.5	38	12	Interpolated
V8 Air Cleaner	1V83912-24-F	32	24	39	12	Interpolated
V8 Air Cleaner	1V83912-29.5-F	39	29.5	39	12	Interpolated
V8 Air Cleaner	1V84312-24-F	35	24	43	12	Interpolated
V8 Air Cleaner	1V84312-29.5-F	43	29.5	43	12	Interpolated
V8 Air Cleaner	1V84812-24-F	39	24	48	12	Interpolated
V8 Air Cleaner	1V84812-29.5-F	48	29.5	48	12	Interpolated
V8 Air Cleaner	1V82618-24-F	28	24	26	18	Interpolated
V8 Air Cleaner	1V82618-29.5-F	34	29.5	26	18	Interpolated
V8 Air Cleaner	1V83018-24-F	31	24	30	18	Interpolated
V8 Air Cleaner	1V83018-29.5-F	38	29.5	30	18	Interpolated
V8 Air Cleaner	1V83418-24-F	34	24	34	18	Interpolated
V8 Air Cleaner	1V83418-29.5-F	42	29.5	34	18	Interpolated
V8 Air Cleaner	1V83818-24-F	38	24	38	18	Interpolated
V8 Air Cleaner	1V83818-29.5-F	46	29.5	38	18	Interpolated
V8 Air Cleaner	1V83918-24-F	39	24	39	18	Interpolated
V8 Air Cleaner	1V83918-29.5-F	47	29.5	39	18	Interpolated
V8 Air Cleaner	1V84318-24-F	42	24	43	18	Interpolated
V8 Air Cleaner	1V84318-29.5-F	51	29.5	43	18	Interpolated
V8 Air Cleaner	1V84818-24-F	46	24	48	18	Interpolated
V8 Air Cleaner	1V84818-29.5-F	56	29.5	48	18	UUT2
V8 Air Cleaner	CP 75-120	10	4.5	8.25	8.25	UUT3

All components shown in Table 1 were manufactured by Dynamic Air Quality Solutions.



REI No: R10-09-22F

Luxemburg, WI 54217 Phone: (920)845-1042

Fax: (920)845-1048 www.rice-inc.com

105 School Creek Trail

UUT#1

Unit Under Test (UUT) Summary Sheet

Manufacturer: **Dynamic Air Quality Solutions**

Model Line: V8 High Efficiency Air Cleaner

Model Number: 1V8-2612-29.5-F

Product Construction Summary:

Filter pads of the air cleaner are a patented combination of medias, bonded together in a frame that seals securely between the hinged aluminum frame of the module. Galvanized steel screens cover each filter pad and filter pads are connected with a galvanized steel frame. The unit has 4 pads per nominal 12" of height. 24Vac is used to polarize fibers in the media and airborne contaminants.

Options/Subcomponent Summary:

The units were stacked in the test structure. The tops and bottoms of the stacks were fastened to a horizontal supporting frame member. Each unit's left and right flange was fastened to a vertical supporting frame member.

UUT Properties


		Dimensions (in)		Lowest Natural Frequency (Hz)			
Weight (lb)	Depth	Width	Height	Front- Back	Side-Side	Vertical	
47	29.5	26	12	N/A	N/A	N/A	


UUT Highest Passed Seismic Test Information

Building Code	Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}
CBC 2016	ICC-ES AC 156	2.49g	1	1.5	3.98g	2.99 g	1.67g	0.67 g

Test Mounting Details:







The units were stacked in the test structure. The tops and bottoms of the stacks were fastened to a horizontal supporting frame member. Each unit's left and right flange was fastened to a vertical supporting frame member. The units were fastened with #8 x 1/2" selftapping screws (qty 4 per unit), torqued to 4 ft/lbs. Fastening was done through the front flange.

The units were also fastened on the backside through horizontal mounting flanges using #10 x 1" self-tapping screws (qty 2 per unit).

The units were full of content during the test, and maintained structural stability and functionality after the test.



105 School Creek Trail Luxemburg, WI 54217 Phone: (920)845-1042 Fax: (920)845-1048 www.rice-inc.com

UUT#2

Unit Under Test (UUT) Summary Sheet

REI No: R10-09-22F

Manufacturer: Dynamic Air Quality Solutions

Model Line: V8 High Efficiency Air Cleaner

Model Number: 1V8-4818-29.5-F

Product Construction Summary:

Filter pads of the air cleaner are a patented combination of medias, bonded together in a frame that seals securely between the hinged aluminum frame of the module. Galvanized steel screens cover each filter pad and filter pads are connected with a galvanized steel frame. The unit has 4 pads per nominal 12" of height. 24Vac is used to polarize fibers in the media and airborne contaminants.

Options/Subcomponent Summary:

The units were stacked in the test structure. The tops and bottoms of the stacks were fastened to a horizontal supporting frame member. Each unit's left and right flange was fastened to a vertical supporting frame member.


	_			
UU	I D	$-\alpha n$	OF	100
$\boldsymbol{\omega}$		-		$I \subset S$

		Dimensions (in) Lowest Natural Frequency (I				ency (Hz)				
					Fro	nt-				
Weight	(lb)	Depth	Width	Height	Ba	ck	Side	-Side	Vertical	
99		29.5	48	18	N/A N/A		/A	N/A		
	UUT Highest Passed Seismic Test Information									
Building Code		Test Criteria	S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}	
CB	CBC 2016		ICC-ES AC 156	2.49 g	1	1.5	3.98 g	2.99 g	1.67 g	0.67 g

Test Mounting Details:







The units were stacked in the test structure. The tops and bottoms of the stacks were fastened to a horizontal supporting frame member. Each unit's left and right flange was fastened to a vertical supporting frame member. The units were fastened with #8 x ½" self-tapping screws (qty 4 per unit), torqued to 4 ft/lbs. Fastening was done through the front flange.

The units were also fastened on the backside through horizontal mounting flanges using #10 x 1" self-tapping screws (qty 2 per unit).

The units were full of content during the test, and maintained structural stability and functionality after the test.

07/02/2017 OSP-0269-10 Page 6 of 7



105 School Creek Trail Luxemburg, WI 54217 Phone: (920)845-1042 Fax: (920)845-1048

www.rice-inc.com

UUT#3

Unit Under Test (UUT) Summary Sheet

REI No: R10-09-22F

Manufacturer: Dynamic Air Quality Solutions

Model Line: V8 High Efficiency Air Cleaner

Model Number: CP 75-120

Product Construction Summary:

A plastic box with a transformer. The CP 75-120 was installed on the exterior side of the frame structure.

Options/Subcomponent Summary:

NA

		U	UT Prope	rties						
		Dimensions (in)	n) Lowest Natural Frequency (Hz)							
Weight (lb)	Depth	Width	Height		Front- Back Side-Side				Vertical	
10	4.50	8.25	8.25	N,	/A	A N/A		N/A		
	UUT Highest Passed Seismic Test Information									
Building Co	Building Code		S _{DS}	z/h	I _p	A _{FLX-H}	A _{RIG-H}	A _{FLX-V}	A _{RIG-V}	
CBC 2016	CBC 2016			1	1.5	3.98 g	2.99 g	1.67 g	0.67 g	

Test Mounting Details:







The CP 75-120 was installed on the side of the frame structure using two #8x1/2" self-tapping screws in each corner of the CP 75-120.

The units was full of content during the test, and maintained structural stability and functionality after the test.

07/02/2017 OSP-0269-10 Page 7 of 7