



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD SPECIAL SEISMIC  
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP – 0305 – 10

OSHPD Special Seismic Certification Preapproval (OSP)

Type: ☐ New ☒ Renewal

Manufacturer Information

Manufacturer: Myers Power Products, Inc.

Manufacturer's Technical Representative: Bruce Steigerwald

Mailing Address: 44 South Commercial Way, Bethlehem, PA 18017

Telephone: 610.868.3500 Email: bruce.steigerwald@myerspower.com

Product Information

Product Name: Illuminator E & IE

Product Type: Lighting Inverter System

Product Model Number: Various (See Attachment)

(List all unique product identification numbers and/or part numbers)

General Description: Single Phase Emergency Lighting Inverter System. Seismic enhancements made to the test units and modifications required to address the anomalies observed during the tests shall be incorporated into the production units.

Mounting Description: Rigid Floor Mounted

Applicant Information


Applicant Company Name: SEESTudio, Inc.

Contact Person: Dan Junker, SE

Mailing Address: 1281 9<sup>th</sup> Ave. San Diego, CA 92101, Suite 1101


Telephone: 619.606.5058 Email: djunker@seestudioinc.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant:  Date: 04-15-16

Title: Principal Engineer Company Name: SEESTudio, Inc.

\*Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs\*





OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION

**California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)**

Company Name: SEESTudio, Inc.

Name: Dan Junker, SE California License Number: S6178

Mailing Address: 1281 9<sup>th</sup> Ave. San Diego, CA 92101, Suite 1101

Telephone: 619.606.5058 Email: djunker@seestudioinc.com

**Supports and Attachments Preapproval**

- ☐ Supports and attachments are preapproved under OPM-  
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- ☒ Supports and attachments are not preapproved

**Certification Method**

- ☒ Testing in accordance with: ☒ ICC-ES AC156
- ☐ Other (Please Specify): \_\_\_\_\_


**Testing Laboratory**

Company Name: Clark Dynamic Test Laboratory, Inc.

Contact Name: Robert Francis, General Manager

Mailing Address: 1801 Route 51 Jefferson Hills, PA 15025

Telephone: 412-387-1004 Email: rfrancis@clarktesting.com





OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT  
FACILITIES DEVELOPMENT DIVISION

**Seismic Parameters**

Design in accordance with ASCE 7-10 Chapter 13: ☒ Yes ☐ No

Design Basis of Equipment or Components ( $F_p/W_p$ ) = 1.80

$S_{DS}$  (Design spectral response acceleration at short period, g) = 2.5

$a_p$  (In-structure equipment or component amplification factor) = 1.0

$R_p$  (Equipment or component response modification factor) = 2.5

$\Omega_0$  (System overstrength factor) = 2.0

$I_p$  (Importance factor) = 1.5

$z/h$  (Height factor ratio) = 1.0

Equipment or Component Natural Frequencies (Hz) = See Attachment

Overall dimensions and weight (or range thereof) = See Attachment

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: ☐ Yes ☒ No

Design Basis of Equipment or Components ( $V/W$ ) = \_\_\_\_\_

$S_{DS}$  (Design spectral response acceleration at short period, g) = \_\_\_\_\_

$S_{D1}$  (Design spectral response acceleration at 1 second period, g) = \_\_\_\_\_

$R$  (Response modification coefficient) = \_\_\_\_\_

$\Omega_0$  (System overstrength factor) = \_\_\_\_\_

$C_d$  (Deflection amplification factor) = \_\_\_\_\_

$I_p$  (Importance factor) = 1.5

Height to Center of Gravity above base = \_\_\_\_\_

Equipment or Component Natural Frequencies (Hz) = \_\_\_\_\_

Overall dimensions and weight (or range thereof) = \_\_\_\_\_

Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No

**List of Attachments Supporting Special Seismic Certification**

☒ Test Report(s) ☐ Drawings ☐ Calculations ☒ Manufacturer's Catalog

☒ Other(s) (Please Specify): SEES Component Certification Summary

**OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022**

Signature: M. R. Karim Date: July 22, 2016

Print Name: M. R. Karim Title: SHFR

Special Seismic Certification Valid Up to :  $S_{DS}$  (g) = 2.50  $z/h$  = 1

Condition of Approval (if applicable): \_\_\_\_\_




TABLE **1**

**TABLE DESCRIPTION:** Lighting Inverters

**S<sub>DS</sub> at z/h = 1.0: S<sub>DS</sub> = 2.5g**

## Page 4 of 13

## SPECIAL SEISMIC CERTIFICATION

# CERTIFIED SUB-COMPONENTS

 TABLE **2**

**MANUFACTURER:** Myers Power Products, Inc.

**MODEL LINE:** Illuminator E & IE Lighting Inverters

**TABLE DESCRIPTION:** Main Transformers

**CONSTRUCTION SUMMARY:**

Copper Windings.

**CERTIFICATION PARAMETERS:**
**Building Code:** CBC 2016

**Component Importance Factor:**  $I_p = 1.5$ 
 **$S_{DS}$  at  $z/h = 1.0$ :**  $S_{DS} = 2.5g$ 
**OPTIONS SUMMARY:**
**MOUNTING SUMMARY:**
**NOTES:**

Mounted in component. Certified mounting shall be identical to mounting of sub-component in UUT's.

| Manufacturer               | Sub-Component    | Model       | Description | UUT |
|----------------------------|------------------|-------------|-------------|-----|
| Myers Power Products, Inc. | Main Transformer | XF-FM114052 |             |     |
|                            |                  | XF-FM114069 |             |     |
|                            |                  | XF-FM114085 |             |     |
|                            |                  | XF-FM114091 |             |     |
|                            |                  | XF-FM114092 |             |     |
|                            |                  | XF-FM114093 |             | 2   |
|                            |                  | XF-FM114095 |             |     |
|                            |                  | XF-FM114096 |             |     |
|                            |                  | XF-FM114097 |             |     |
|                            |                  | XF-FM114098 |             |     |
|                            |                  | XF-FM114100 |             |     |
|                            |                  | XF-FM114101 |             |     |
|                            |                  | XF-FM114102 |             |     |
|                            |                  | XF-FM114103 |             | 1   |
|                            |                  | XF-FM114116 |             |     |
|                            |                  | XF-FM114255 |             |     |
|                            |                  | XF-FM114258 |             |     |
|                            |                  | XF-FM114271 |             |     |
|                            |                  | XF-FM114309 |             |     |
|                            |                  | XF-FM114310 |             |     |
|                            |                  | XF-FM114387 |             |     |
|                            |                  |             |             |     |
|                            |                  |             |             |     |
|                            |                  |             |             |     |
|                            |                  |             |             |     |

## SPECIAL SEISMIC CERTIFICATION

# CERTIFIED SUB-COMPONENTS

 TABLE **3**

**MANUFACTURER:** Myers Power Products, Inc.

**MODEL LINE:** Illuminator E & IE Lighting Inverters

**TABLE DESCRIPTION:** Option Transformers

**CONSTRUCTION SUMMARY:**

Copper Windings.

**CERTIFICATION PARAMETERS:**
**Building Code:** CBC 2016

**Component Importance Factor:**  $I_p = 1.5$ 
 **$S_{DS}$  at  $z/h = 1.0$ :**  $S_{DS} = 2.5g$ 
**OPTIONS SUMMARY:**
**MOUNTING SUMMARY:**
**NOTES:**

Mounted in component. Certified mounting shall be identical to mounting of sub-component in UUT's.

| Manufacturer               | Sub-Component      | Model       | Description | UUT |
|----------------------------|--------------------|-------------|-------------|-----|
| Myers Power Products, Inc. | Option Transformer | XF-IS104781 |             |     |
|                            |                    | XF-IS103534 |             |     |
|                            |                    | XF-IS106435 |             |     |
|                            |                    | XF-AU112788 |             |     |
|                            |                    | XF-AU102331 |             |     |
|                            |                    | XF-AU101656 |             |     |
|                            |                    | XF-AU104304 |             |     |
|                            |                    | XF-IS103533 |             |     |
|                            |                    | XF-IS102796 |             |     |
|                            |                    | XF-IS114851 |             |     |
|                            |                    | XF-IS114849 |             |     |
|                            |                    | XF-IS105786 |             |     |
|                            |                    | XF-AU104125 |             |     |
|                            |                    | XF-AU101612 |             |     |
|                            |                    | XF-IS105727 |             |     |
|                            |                    | XF-IS105152 |             |     |
|                            |                    | XF-IS114673 |             |     |
|                            |                    | XF-IS113259 |             |     |
|                            |                    | XF-AU113859 |             |     |
|                            |                    | XF-AU103093 |             |     |
|                            |                    | XF-IS102834 |             |     |
|                            |                    | XF-IS110554 |             | 2   |
|                            |                    | XF-IS102389 |             |     |
|                            |                    | XF-AU108550 |             |     |
|                            |                    | XF-AU102316 |             | 2   |
|                            |                    | XF-IS103822 |             |     |

SPECIAL SEISMIC CERTIFICATION

# CERTIFIED SUB-COMPONENTS

TABLE **3**

**MANUFACTURER:** Myers Power Products, Inc.  
**MODEL LINE:** Illuminator E & IE Lighting Inverters  
**TABLE DESCRIPTION:** Option Transformers

**CONSTRUCTION SUMMARY:**

Copper Windings.

**CERTIFICATION PARAMETERS:**

**Building Code:** CBC 2016

**Component Importance Factor:**  $I_p = 1.5$

**$S_{DS}$  at  $z/h = 1.0$ :**  $S_{DS} = 2.5g$

**OPTIONS SUMMARY:**

**MOUNTING SUMMARY:**

**NOTES:**

Mounted in component. Certified mounting shall be identical to mounting of sub-component in UUT's.

| Manufacturer               | Sub-Component      | Model       | Description | UUT |
|----------------------------|--------------------|-------------|-------------|-----|
| Myers Power Products, Inc. | Option Transformer | XF-IS107057 |             |     |
|                            |                    | XF-IS101765 |             |     |
|                            |                    | XF-AU102839 |             |     |
|                            |                    | XF-AU102077 |             |     |
|                            |                    | XF-IS114870 |             |     |
|                            |                    | XF-IS104645 |             |     |
|                            |                    | XF-IS103354 |             |     |
|                            |                    | XF-IS111113 |             |     |
|                            |                    | XF-IS102141 |             |     |
|                            |                    | XF-AU101676 |             |     |
|                            |                    | XF-IS102833 |             |     |
|                            |                    | XF-AU102444 |             |     |
|                            |                    | XF-AU106763 |             |     |
|                            |                    | XF-IS104920 |             |     |
|                            |                    | XF-IS114739 |             |     |
|                            |                    | XF-AU109375 |             |     |
|                            |                    | XF-AU102474 |             |     |
|                            |                    | XF-IS114621 |             | 1   |
|                            |                    | XF-IS113294 |             |     |
|                            |                    | XF-IS111755 |             |     |
|                            |                    | XF-IS110639 |             |     |
|                            |                    | XF-AU111057 |             |     |
|                            |                    | XF-AU105078 |             |     |
|                            |                    |             |             |     |
|                            |                    |             |             |     |
|                            |                    |             |             |     |



## TABLE 4

**TABLE DESCRIPTION:** Batteries & Fuses

## MOUNTING SUMMARY:

Mounted in component. Certified mounting shall be identical to mounting of sub-component in UUT's.

S E E T O M O R R O W B U I L T T O D A Y

**Document No.: 2016-015-CCS-001.0**





## TABLE 5

**TABLE DESCRIPTION:** Miscellaneous Sub-Components

Mounted in component. Certified mounting shall be identical to mounting of sub-component in UUT's.

Document No.: 2016-015-CCS-001.0

SPECIAL SEISMIC CERTIFICATION

# UNIT UNDER TEST (UUT) DESCRIPTION

UUT **1**

**MANUFACTURER:** Myers Power Products, Inc.  
**MODEL LINE:** Illuminator E & IE Lighting Inverters  
**MODEL NUMBER:** 16.7 kVA

## CONSTRUCTION SUMMARY:

Powder-coated Cold-rolled. Lockable hinged doors. Certified unit construction shall be identical to cabinet construction of UUT's.

## OPTIONS SUMMARY:

Myers Power IC2-Fax/Modem-2, Precision Graphics 403833 Status monitoring, Newport Electronics EIS-W SNMP, Precision Graphics 403492, Stagger Start Option, Deltrol Controls 160 Series Options Relay, ABB S2C-H6R Output Trip Option, Schneider Electric MG26928 Output Trip Option, Kraus & Naimer 600 E Series Maintenance Bypass, Myers Power SA-403244 AC Sub-Assembly, Myers Power SA-403246 DC Sub-Assembly, Myers Power XF-FM114103 Main Transformer, Myers Power XF-IS114621 Option Transformer, Little Fuse NLN Series Fuse, Marathon F60A1B Fuse Block, East Penn Mfg. 12AVR100-3ET Batteries, Leoch FT12-100 Batteries

## TEST PARAMETERS:

**Building Code:** CBC 2016

**Component Importance Factor:**  $I_p = 1.5$

**Test Criteria:** AC-156

## MOUNTING SUMMARY:

Rigid floor mounted. Unit mounted to shake table at ends with a total of ten (10) 5/8" Gr. 5 bolts.

## NOTES:

Contents were included in testing per operating conditions.

## UUT IMAGE



## UUT PROPERTIES

| Dimensions (in) |       |        | Weight (lb) | First Natural Frequency (Hz) |      |       |
|-----------------|-------|--------|-------------|------------------------------|------|-------|
| Depth           | Width | Height |             | F-B                          | S-S  | Vert  |
| 25.0            | 48.0  | 76.0   | 4,280       | 19.1                         | 11.3 | >33.0 |

## UNIT MAINTAINED STRUCTURAL INTEGRITY AND REMAINED OPERATIONAL

PER MANUFACTURER REQUIREMENT WHEN SUBJECTED TO THE FOLLOWING TEST PARAMETERS

| $S_{Ds}$ (g) | $z/h$ | $A_{FLX-H}$ (g) | $A_{RIG-H}$ (g) | $A_{FLX-V}$ (g) | $A_{RIG-V}$ (g) |
|--------------|-------|-----------------|-----------------|-----------------|-----------------|
| 2.5          | 1.0   | 4.0             | 3.0             | 1.67            | 0.67            |



SPECIAL SEISMIC CERTIFICATION

# UNIT UNDER TEST (UUT) DESCRIPTION

UUT **1**

**MANUFACTURER:** Myers Power Products, Inc.  
**MODEL LINE:** Illuminator E & IE Lighting Inverters  
**MODEL NUMBER:** 16.7 kVA

## SUPPORT AND ATTACHMENT SUMMARY:



SPECIAL SEISMIC CERTIFICATION

# UNIT UNDER TEST (UUT) DESCRIPTION

UUT **2**

**MANUFACTURER:** Myers Power Products, Inc.  
**MODEL LINE:** Illuminator E & IE Lighting Inverters  
**MODEL NUMBER:** 5 kVA

## CONSTRUCTION SUMMARY:

Powder-coated Cold-rolled. Lockable hinged doors. Certified unit construction shall be identical to cabinet construction of UUT's.

## OPTIONS SUMMARY:

Myers Power IC2-Fax/Modem-1, Precision Graphics 403833 Status monitoring, Newport Electronics EIS-W SNMP, Precision Graphics 403492, Stagger Start Option, Deltrol Controls 160 Series Options Relay, ABB S2C-H6R Output Trip Option, Schneider Electric MG26928 Output Trip Option, Kraus & Naimer 600 E Series Maintenance Bypass, Myers Power SA-403245 AC Sub-Assembly, Myers Power SA-403243 DC Sub-Assembly, Myers Power XF-FM114092 Main Transformer, Myers Power XF-IS110554 & XF-AU102316 Option Transformers, Little Fuse NLN Series Fuse, Marathon F60A1B Fuse Block, East Penn Mfg. 12AVR100-3ET Batteries, Leoch FT12-100 Batteries

## TEST PARAMETERS:

**Building Code:** CBC 2016

**Component Importance Factor:**  $I_p = 1.5$

**Test Criteria:** AC-156

## MOUNTING SUMMARY:

Rigid floor mounted. Unit mounted to shake table at ends with a total of four (4) 5/8" Gr. 5 bolts

## NOTES:

Contents were included in testing per operating conditions.

## UUT IMAGE



## UUT PROPERTIES

| Dimensions (in) |       |        | Weight (lb) | First Natural Frequency (Hz) |      |      |
|-----------------|-------|--------|-------------|------------------------------|------|------|
| Depth           | Width | Height |             | F-B                          | S-S  | Vert |
| 25.0            | 30.0  | 62.0   | 1,465       | 14.9                         | 10.0 | 21.7 |

## UNIT MAINTAINED STRUCTURAL INTEGRITY AND REMAINED OPERATIONAL

PER MANUFACTURER REQUIREMENT WHEN SUBJECTED TO THE FOLLOWING TEST PARAMETERS

| $S_{Ds}$ (g) | $z/h$ | $A_{FLX-H}$ (g) | $A_{RIG-H}$ (g) | $A_{FLX-V}$ (g) | $A_{RIG-V}$ (g) |
|--------------|-------|-----------------|-----------------|-----------------|-----------------|
| 2.5          | 1.0   | 4.0             | 3.0             | 1.67            | 0.67            |



SPECIAL SEISMIC CERTIFICATION

## UNIT UNDER TEST (UUT) DESCRIPTION

UUT **2**

**MANUFACTURER:** Myers Power Products, Inc.  
**MODEL LINE:** Illuminator E & IE Lighting Inverters  
**MODEL NUMBER:** 5 kVA

### SUPPORT AND ATTACHMENT SUMMARY:

