

APPLICATION FOR OSHPD SPECIAL SEISMIC	OFFIC	E USE ONLY
CERTIFICATION PREAPPROVAL (USP)	APPLICATION #:	OSP – 0528 – 10
OSHPD Special Seismic Certification Preapproval (OSP)		
Type: 🛛 New 🗌 Renewal		
Manufacturer Information		
Manufacturer: Toshiba International Corporation		
Manufacturer's Technical Representative: Jesús Peñalver		
Mailing Address:13131 West Little York Road, Houston, TX 77041		
Telephone: <u>855.803.7087 ext. 3649</u> Email: jesus.p	<u>enalver@toshiba.com</u>	
Product Information		
Product Name: G9000 & G2020 Uninterruptible Power Systems		
Product Type:Uninterruptible Power System		
Product Model Number: See Attachment 1		
General Description: UPS with carbon steel enclosures and Si & Si	<u>C pow</u> er modules.	
Seismic enhancements made to the test unit shall be incorporated in	to the respective produ	ction units.
Mounting Description: Rigid floor mounted		
Applicant Information		
Applicant Company Name: <u>Manwill Engineering LLC</u>		
Contact Person: Derek Manwill, SE		
Mailing Address: PO Box 1194, Bend, OR 97709		
Telephone: <u>541.241.2102</u> Email: <u>derek(</u>	<u>@manwillSE.com</u>	
I hereby agree to reimburse the Office of Statewide Health I accordance with the California Administrative Code, 2016.	Planning and Devel	opment review fees in
Signature of Applicant:	Date	e: June 30, 2017
Title: President Company Name: Manw	ill Engineering LLC	
"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"	All All Ann	OSHPD

STATE OF CALIFORNIA – HEALTH AND HUMAN SERVICES AGENCY OSH-FD-759 (REV 12/16/15)

Page 1 of 3



California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)								
Company Name: Manwill Engineering LLC								
Name: Derek Manwill, SE California License Number: S6266								
Mailing Address: _ PO Box 1194, Bend, OR 97709								
Telephone: 541.241.2102 Email: derek@manwillSE.com								
Supports and Attachments Preapproval								
 Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required) Supports and attachments are not preapproved 								
Certification Method								
 Testing in accordance with: ICC-ES AC156 Other (Please Specify):								
Testing Laboratory								
Company Name: Environmental Testing Laboratory								
Contact Name: Jeremy Lange								
Mailing Address:11034 Indian Trail, Dallas, TX 75229								

 Telephone:
 972.247.9657
 Email:
 jeremy@etIdallas.com

"Access to Safe, Quality Healthcar	e Environments that Meet	California's Diverse and	I Dynamic Needs
------------------------------------	--------------------------	--------------------------	-----------------



OSP-0528-10

Page 2 of 3

OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismi	ic Param	eters
--------	----------	-------

Design in accordance with ASCE 7-10 Chapter 13: 🛛 Yes 🗌 No
Design Basis of Equipment or Components (Fp/Wp) = <u>1.16 (Sps = 1.54g); 0.90 (Sps = 2.0g)</u>
S_{DS} (Design spectral response acceleration at short period, g) = 1.54 (z/h = 1); 2.0 (z/h = 0)
a_p (In-structure equipment or component amplification factor) = <u>2.5</u>
R _p (Equipment or component response modification factor) = <u>6.0</u>
Ω_0 (System overstrength factor) =20
I_p (Importance factor) = 1.5
z/h (Height factor ratio) = _1 (S _{DS} = 1.54g); 0 (S _{DS} = 2.0g)
Equipment or Component Natural Frequencies (Hz) = <u>See Attachment 2</u>
Overall dimensions and weight (or range thereof) = <u>See Attachments 1 & 2</u>
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: 🗌 Yes 🛛 No
Design Basis of Equipment or Components (V/W) =
S _{DS} (Design spectral response acceleration at short period, g) =
S _{D1} (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) =
Ω_0 (System overstrength factor) =
C₄ (Deflection amplification factor) =
$I_{\rm p}$ (Importance factor) = 1.5
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015:
List of Attachments Supporting Special Seismic Certification
Test Report(s)
Other(s) (Please Specify): Attachments 1, 2, & 3
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
a 1/1/1/1
Signature: Date: July 27, 2017
Print Name: Title: Title: SSE
Special Seismic Certification Valid Up to : S _{DS} (g) = <u>See Above</u> z/h = <u>See Above</u>
Condition of Approval (if applicable):
"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"
STATE OF CALIFORNIA - HEALTH AND HUMAN SERVICES AGENCY
USH-FD-759 (REV 12/16/15) Page 3 of 3

ATTACHMENT 1: CERTIFIED COMPONENTS

SEISMIC COMPLIANCE REPORT

TABLE 1

DOCUMENT NO.: 17011CR1.0

TOSHIBA

MANUFACT	URER:	ER: TOSHIBA INTERNATIONAL CORPORATION										
PRODUCT F	AMILY:	G9000 A	ND G2020 U	ININTERRU	PTIBLE PO	WER SYSTE	EMS					
			DI	MENSIONS	(in)	MAX. WT.		PASIS				
			DEPTH	WIDTH	HEIGHT	(lb)		DAJIJ				
G9000 Uninter	ruptible	Power Syst	tems									
T9X ^[1] S3S10KS	36XSN2 (100kVA)	32.7	27.6	78.7	772	See Note 1 below	EXTRAP				
T9XS3S10KS6	3XSN (100	JkVA)	32.8	27.6	78.7	866	Si power modules, carbon steel encl.	UUT 1				
T9XS3S16KS6	3XSN2 (16	j0kVA)	32.7	27.6	78.7	860		INTERP				
T9XS3S16KS6	3XSN (160	JkVA)	32.7	35.4	78.7	1200		INTERP				
T9XS3S22KS6	3XSN2 (22	25kVA)	32.7	35.4	78.7	1080		INTERP				
T9XS3S22KS6	3XSN (225	kVA)	32.7	35.4	78.7	1250		INTERP				
T9XS3S30KS6	3XSN (300	JkVA)	32.8	51.2	78.7	2260		INTERP				
T9XS3S50KS6	3XSN (500	JkVA)	32.8	70.9	78.7	3300		INTERP				
T9XS3S65KS6	3XSN (650	JkVA)	32.8	90.6	78.7	4062		INTERP				
T9XS3S75KS6	3XSN (750	JkVA)	32.8	90.6	78.7	4062	Si power modules, carbon steel encl.	UUT 2				
G2020 Uninter	ruptible	Power Syst	tems									
T200H0500KV	VWW (500	JkVA)	33.5	59.1	78.7	2756		INTERP				
T200H0750KW	VWW (750	JkVA)	33.5	81.6	78.7	3565	SiC power module, carbon steel encl.	UUT 3				
MOUNTING:	Rigid floo	or mounted.				SEISMIC LEVEL(S)	$S_{DS} = 1.54g$ for z/h = 1 $S_{DS} = 2.0g$ for z/h = 0	I _P = 1.5				
NOTES:	INTING: Rigid floor mounted. Image: Second state of the point of the poin											

ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

UUT 1 - G9000 100kVA

MANUFA	MANUFACTURER: TOSHIBA INTERNATIONAL CORPORATION											
MODEL	NUMBER:	T90S3S10KS6XSN (100kVA)										
UNIT FUI	NCTION:	Uninterruptible power system										
SERIAL I	RIAL NUMBER: 08-7E445120012											
DI	MENSIONS	(in)	WEIGHT	RES. F	REQ.	. (Hz)	1					
DEPTH	WIDTH	HEIGHT	(lb)	F-B	S-S	V						
32.8	27.6	78.7	866	7.9	5.0	18.9						
BUILDIN	IG CODE	TEST C	RITERIA	LAB REPORT NO.								
2016	CBC	ICC-ES	AC156	ETL S	Q37-10	010-1						
S _{DS} (g)	z/h	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g) A _F	_{RIG-V} (g)						
1.54	1	2.46	1 95	1 24		0.54						
2.0	0	2.40	1.00	1.34		0.54						

IMPORTANCE FACTOR, $I_P = 1.5$

Unit was full of operating content during the shake table test. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

MOUNTING:	Rigid floor mounted using (4) 1/2" ASTM A307 bolts.
CONSTRUCTION:	NEMA 1 carbon steel enclosure, Si power modules.
SUBCOMPONENTS:	Subcomponents uniquely identified by model number.
TESTING NOTES:	No 45-degree performed on uniaxial. Therefore, values have been adjusted down by a factor of 1.3 for orthogonality.

UUT 2 - G9000 750kVA

	CTUDED.	TOCHIDA						
WANUFA	CIUKER.		INTERNATIO	NAL CORFO	JRATION			
MODEL	JUMBER:	T90S3S75	T90S3S75KS6XSN (750kVA)					
UNIT FUI	NCTION:	Uninterrup	tible power sy	stem				
SERIAL N	NUMBER:	09-7E4157	/10081					
DIN	MENSIONS	(in)	WEIGHT	RES. F	RES. FREQ. (Hz)			
DEPTH	WIDTH	HEIGHT	(lb)	F-B 🗧	3-S V			
32.8	90.6	78.7	4062	5.8	5.4 5.7			
BUILDIN	G CODE	TEST C	RITERIA	LAB RE	PORT NO.			
2016	CBC	ICC-ES AC156		C156 ETL SQ				
S _{DS} (g)	z/h	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)			
1.54	1	2.46	4 95	1 24	0.54			
2.0	0	2.40	1.05	1.34	0.54			
IMPORTA Unit was fu structural in shake table	2.002.401.051.340.34 IPORTANCE FACTOR, I P $I.5$ nit was full of operating content during the shake table test. Unit maintained ructural integrity and remained functional per manufacturer requirement after nake table test.							
MOUNTI	NG:	Rigid floor	mounted usin	ıg (10) 5/8" A	STM A307 bo'			
CONSTR	UCTION:	NEMA 1 cr	arbon steel er	closure, Si p	ower modules			
SUBCOM	IPONENTS:	Subcompc	nents unique	y identified b	y model numb			
TESTING	NOTES:	No 45-deg	,ree performec	l on uniaxial.	Therefore, val			



derek@manwillSE.com



SEISMIC COMPLIANCE REPORT DOCUMENT NO.: 17011CR1.0

MANWILL ENGINEERING

ATTACHMENT 2: UNIT UNDER TEST SUMMARIES

SEISMIC COMPLIANCE REPORT

TOSHIBA

Ul

JUT 3	- G2020	750kV	4					DOCUMENT	NO.: 17011CR1.0 ا
MANUFA	CTURER:	TOSHIBA	INTERNATIO	NAL COF	RPORAT	ION		AND PL	
MODEL N	NUMBER:	T200H075	0KWWW (750	kVA)					
UNIT FUI	NCTION:	Uninterrup	tible power sys	stem				No.	
SERIAL I	NUMBER:	17530069							0
DI	MENSIONS ((in)	WEIGHT	RES	. FREQ	. (Hz)	- marine the		
DEPTH	WIDTH	HEIGHT	(lb)	F-B	S-S	V	Statements of the second		and the second second
33.5	81.6	78.7	3565	5.6	9.1	17.3	The second se		
BUILDIN	IG CODE	TEST C	RITERIA	LAB	REPOR	T NO.			
2016	; CBC	ICC-ES	AC156	ETL 17011TR1				·····	
S _{DS} (g)	z/h	А _{гі х-н} (g)	A _{RIG-H} (g)	A _{FLX-V}	(g) A _{RIG-V} (g)		dert detter		
	+							國語語 日本	
2.0	1	3.20	2.40	1.34	;	0.54			
2.0 IMPORT/ Unit was fu structural in shake table	1 ANCE FACT Ill of operating ntegrity and re e test.	3.20 OR, I _P = 1.5 content durin mained functi	2.40 Ig the shake ta onal per manu	1.34 Ible test. Ifacturer I	Unit mair requirem	0.54 ntained ent after			
2.0 IMPORT/ Unit was fu structural in shake table	1 ANCE FACT Ill of operating ntegrity and re e test. NG:	3.20 OR, I _P = 1.5 content durin mained functi Rigid floor	2.40 Ing the shake ta onal per manu mounted usin	1.34 able test. Jfacturer 1 g (6) 5/8"	Unit mair requirem Grade 8	0.54 ntained ent after bolts.			
2.0 IMPORT/ Unit was fu structural ii shake table MOUNTII CONSTR	ANCE FACT ull of operating ntegrity and re e test. NG: UCTION:	3.20 OR, I _P = 1.5 content durin mained functi Rigid floor NEMA 1 ca	2.40 Ig the shake ta onal per manu mounted using arbon steel en	1.34 able test. Ifacturer i g (6) 5/8" closure, S	Unit mair requirem Grade 8 SiC powe	0.54 ntained ent after bolts.	S.		
2.0 IMPORT/ Unit was fu structural in shake table MOUNTII CONSTR SUBCOM	1 ANCE FACT ull of operating ntegrity and re e test. NG: UCTION: IPONENTS:	3.20 OR, I _P = 1.5 content durin mained functi Rigid floor NEMA 1 ca Subcompo	2.40 Ig the shake ta ional per manu mounted usin arbon steel en nents uniquel	1.34 able test. Ifacturer I g (6) 5/8" closure, S / identifie	Unit mair requirem Grade 8 SiC powe d by mod	0.54 ntained ent after bolts. r module jel numbo	s. F.		

MANWILL ENGINEERING

ATTACHMENT 3: MODEL NOMENCLATURE

SEISMIC COMPLIANCE REPORT

TOSHIBA

60000

G9000																					DC	CL	JME	NT	NO	.: 17	701 [,]	ICF	1.0
DIGIT:	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	-	-	-	-	-	-	-	-	-	-	-	-	-	-
SAMPLE:	T	9	0	S	3	S	1	0	Κ	S	6	X	S	Ν	2	-	-	-	-	-	-	-	-	-	-	-	-	-	-
DIGIT	DIGI	T DE	SCI	RIPT	ION						(COD	ES	C	DEFI	ΝΙΤΙ	ONS	S											
1-2	Produ	ıct lin	e								٦	Г9		G	9000) Sei	ries												
3	Contr	oller	Gene	eratio	n						C)		G	Gener	atior	ר 1												
											1			G	Sener	atior	1 2												
4	Input/	Outp	ut Vo	oltage	е						5	3		4	80V 3	3-Ph	ase/	3-Wi	ire +	Gnd									
5	Phase	e Inpi	ut/Ou	utput							3	3		Т	hree	Pha	se Ir	nput/	Outp	ut									
6	Input/	Outp	ut Vo	oltage	е						S	3	480V 3-Phase/3-Wire + Gnd																
7-9	kVA F	Rating	g								1	I0K		1	00kV	Ά													
											1	l6K		1	160kVA														
											2	22K		225kVA															
											3	30K		300kVA															
											5	50K		5	00kV	Ά													
											6	65K		6	50kV	Ά													
											7	′5K		7	50kV	Ά													
10	Altern	ate I	nput								U)	3		4	80V 3	3-Ph	ase/	3-Wi	ire										
11	Outpu	ıt Fre	quer	ιсу							6	3		6	0Hz														
12	Maint	enan	ce B	ypas	s Op	tion)	()	X	N	lot In	clude	ed												
13	Optio	ns 1	Mode	əl							5	3		Single Module (Standard)															
14	UPS ⁻	Туре									٢	J		N	lew L	Jnit													
							. <				F	ર		R	lefurk	oishe	ed												
15	Enhar	nced	Mod	el							-			G	Gener	atior	ח 1 N	lode	l										
											2)		F	nhan	red	Mod	<u>م</u> ا ((ene	ation	ר 2								

G2020

DIGIT:		11 12 13									
SAMPLE	2 0 0 H 0 7 5 0 K	w w w	- - - - - - - - - -								
DIGIT	DIGIT DESCRIPTION	CODES	DEFINITIONS								
1-3	Product line	T20	G2020 Series								
4	Revision Number	0	0								
5	Phase/Frequency	Н	3 Phase in/3 Phase Out 60 Hz								
6-10	kVA Rating	0500K	500kVA								
		0750K	750kVA								
11	Input Voltage	W	480V								
12	Output Voltage	W	480V								
13	Bypass Voltage	W	480V								