OFFICE USE ONLY APPLICATION FOR OSHPD SPECIAL SEISMIC **CERTIFICATION PREAPPROVAL (OSP)** APPLICATION #: OSP - 0601 - 10 **OSHPD Special Seismic Certification Preapproval (OSP)** New □ Renewal **Manufacturer Information** Manufacturer: Daikin Applied Manufacturer's Technical Representative: Art Rizoli Mailing Address: 207 Laurel Hill Rd., Verona, VA 24482 Telephone: 540.248.9539 Email: Mad Art.rizoli@daikinapplied.com **Product Information** Magnitude® Magnetic Bearing Centrifugal Chillers (WME Water Cooled Chillers Product Type: Product Model Number: Varies (List all unique product identification numbers and/or part numbers) General Description: Centrifugal Chillers. Seismic enhancements made to the test units required to address the anomalies observed during the tests shall be incorporated into the production units. Mounting Description: Base mounted - neoprene isolated **Applicant Information** Applicant Company Name: Structural Integrity Associates, Inc. dba TRU Compliance Contact Person: Andrew M. Coughlin, SE Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138 Telephone: 844-878-0200 Email: acoughlin@structint.com I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016. Signature of Applicant: Date: 4/23/2019 Title: Director, TRU Compliance Company Name: Structural Integrity Associates, Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)
Company Name: Structural Integrity Associates, Inc.
Name: Andrew M. Coughlin California License Number: S6082
Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138
Telephone: 844-878-0200 Email: acoughlin@structint.com
· — — — — — — — — — — — — — — — — — — —
Supports and Attachments Preapproval
Supports and attachments are preapproved under OPM- (Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
Supports and attachments are not preapproved
Certification Method
□ Testing in accordance with:
BY: Timothy J. Piland
Testing Laboratory DATE: 05/07/2019
Company Name: PEER, UC Berkeley
Contact Name: Alex R. Mead
Mailing Address: 1302 South 46th Street, Richmond CA 94804
Telephone: (616) 901-2479 Email: Alex.r.mead@gmail.com
U.S. Army Engineer Research and Development Center, Construction Engineering Research Laboratory (ERDC-CERL)
Contact Name: Jim Wilcoski
Mailing Address: 2902 Newmark Dr. Champaign, IL 61822
Telephone: (217) 373-6763 Email: james.wilcoski@usace.army.mil

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





Page 2 of 22

05/07/2019 OSP-0601-10



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters
Design in accordance with ASCE 7-10 Chapter 13: ⊠ Yes □ No
Design Basis of Equipment or Components (F _p /W _p) = 1.50 @ S _{DS} = 2.00, z/h = 1; 1.13 @ S _{DS} = 2.50, z/h = 0
S _{DS} (Design spectral response acceleration at short period, g) = 2.00 @ z/h = 1.0; 2.50 @ z/h = 0.0
a _p (In-structure equipment or component amplification factor) = 2.5
R _p (Equipment or component response modification factor) = 6.0
Ω_0 (System overstrength factor) = 2.0
I _p (Importance factor) = 1.5
z/h (Height factor ratio) = 1 @ S _{DS} = 2.00; 0 @ S _{DS} = 2.50
Equipment or Component Natural Frequencies (Hz) = See Attachment
Overall dimensions and weight (or range thereof) = See Attachment
Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: Yes No
Design Basis of Equipment or Components (V/W) =
S _{DS} (Design spectral response acceleration at short period, g) =
S _{D1} (Design spectral response acceleration at 1 second period, g) =
R (Response modification coefficient) = OSP-0601-10
Ω_0 (System overstrength factor) =
C _d (Deflection amplification factor) = BY: Timothy J. Piland
I _P (Importance factor) = 1.5
Height to Center of Gravity above base =
Equipment or Component Natural Frequencies (Hz) =
Overall dimensions and weight (or range thereof) =
Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☑ No
List of Attachments Supporting Special Seismic Certification
OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2022
1./ 1 00
Signature: Date: May 7, 2019
Print Name: Timothy J. Piland Title: SSE
Special Seismic Certification Valid Up to: S _{DS} (g) = See Above z/h = See Above
Condition of Approval (if applicable):

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





Page 3 of 3

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

TRU PROJECT NO. 1700688



Manufacturer: Daikin Applied

Model Line: Magnitude Magnetic Bearing Centrifugal Chillers

TABLE 1

Certified Product Construction Summary:

Carbon Steel

Certified Options Summary:

Subcomponents and options are summarized in Table 2 and Table 3.

Mounting Configuration:

Base mounted - rigid & neoprene isolated

Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.

Building Code: CBC 2016

Seismic Certification Limits:

 $S_{DS} = 2.0 g$ z/h=1.0 $S_{DS} = 2.5 g$ z/h=0.0

I_P= 1.5

Madallina		Dir	mensions (i	in) ²	Weight	No.	
Model Line	Model ¹	Depth	Width	Height	(lb) ³	Notes	UUT
Magnitude Magnetic Bearing Centrifugal Chillers, Model WMC	WMC060DC/E3009	168.5 ¹¹	imo _{55.2}	J · 94.3 l a	an <mark>9</mark> ,555	0	3
	WME501 E3012/C2612	D168 E :	: 056807	/2979	14,307	7	Interp.
 -	WME501 E3012/C3012	168	71	101	15,958		Interp.
	WME501 E3612/C3012	170	71	116	18,709	/	Interp.
 	WME701 E3612/C3612	170	88	107	22,478		Interp.
 	WME701 E3612/C3012	170	85	101	19,423		Interp.
 	WME092AS	194.9	96.1 D	I 102.7	25,557		Interp.
Magnitude® Magnetic	WME092BS	194.9	96.1	102.7	25,557		Interp.
Bearing Centrifugal Chillers, Model WME,	WME106AS	195.1	101.8	108.7	30,731		Interp.
400-1600 tons	WME106BS	195.2	101.8	108.7	30,371		Interp.
100 1000 105	WME092AD	252	116	110	48,490		Interp.
 	WME092BD	252	116	110	48,490		Interp.
 	WME106AD	252	116	110	48,490		Interp.
	WME106BD	252	116	110	48,490		Interp.
	WME099AD	252	116	110	48,490		Interp.
	WME099BD	252	116	110	48,490		4
<i>1</i>	1	1	1	1	,		

Notes:

¹ WME 501/701 are identical to WME096/099/106 except for software.

²All WME model configurations limited to dimensions of UUT 4.

³All WME model configurations limited to the weight of UUT 4.

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

TRU PROJECT NO. 1700688



Manufacturer: Daikin Applied **Table Description:** Compressor, Evaporator and Condensors **TABLE 2** Model Line: Magnitude Magnetic Bearing Centrifugal Chillers

 $S_{DS} = 2.0 g z/h = 1.0$ $I_P = 1.5$ Building Code: CBC 2016 **Seismic Certification Limits:**

Component Type	Manufacturer	Model	Description	Notes	UUT
Compressor	Danfoss/Turbocor	TT700	380V to 460V, 318 lbs., 20.4"x31"x19.2"	Magnetic Bearing Compressor with Integral Motor and Variable Frequency Drive (Cast Aluminum Shell)	3
Compressor		092A	32.91"d x 44.85"w x 24.5"h, 961 lbs.		4
	Daikin	092B	32.91"d x 44.85"w x 24.5"h, 961 lbs.	Magnetic Bearing Compressor	Interp
	Dalkill	106A BY:	35.21"d x 44.95"w x 25.2"h, 1118 lbs.	(Carbon Steel)	4
		106B	35.21"d x 44.95"w x 25.2"h, 1118 lbs.		Interp
		E2209 DAT	E 220 6 x/90 h, 1624 lbs.		Extrap
		E2212	22"ø x 12"h, 2803 lbs.		Extrap
		E2609	26"ø x 9"h, 2271 lbs.		Extrap
Fyanorator	Daikin	E2612	26"ø x 12"h, 2907 lbs.	Carbon Steel ASME Shell with Copper	Extrap
Evaporator	Dalkill	E3009	30"ø x 9"h, 3032 lbs.	Tubes	3
		E3012	30"ø x 12"h, 3, 861lbs.		Interp
		E3612	36"ø x 12"h, 5,669 lbs.		Interp
		E4216	42"ø x 16"h, 10,200 lbs.		4

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

TRU PROJECT NO. 1700688



Manufacturer: Daikin Applied Table Description: Compressor, Evaporator and Condensors Magnitude Magnetic Bearing Centrifugal Chillers

Table Description: Compressor, Evaporator and Condensors Magnitude Magnetic Bearing Centrifugal Chillers

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \text{ g}$ z/h = 1.0 $I_P = 1.5$

suitaing Code: CBC 201		Seismic Certification Limits: $S_{DS} = 2.5 g z/h = 0.0$						
Component Type	Manufacturer	Model	Description	Notes	UUT			
		C2009	20"ø x 9"h, 1926 lbs.		Extrap			
		C2012	20"ø x 12"h, 2381 lbs.		Extrap			
		C2209	22"ø x 9"h, 2228 lbs.		Extrap			
		C2212	22"ø x 12"h, 2716 lbs.		Extrap			
6 1	Daikin	C2609	26"ø x 9"h, 3189 lbs.	Carbon Steel ASME Shell with Copper	3			
Condenser	Daikin	C2612	26"ø x 12"h, 3,806 lbs.	Tubes	Interp			
		C3012 BY:	30"ø x 12"h, 5,011 lbs.		Inter			
		C3612	36"ø x 12"h, 7264 lbs.		Inter			
		C4212 DAT			Inter			
		C4216	42"ø x 16"h, 13,367 lbs.		4			
		(12)						
		PA	\$ \$					
		TA.	CO					
			BUILDING					

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

TRU PROJECT NO. 1700688



Manufacturer: Daikin Applied Table Description: Electrical Subcomponents

Model Line: Magnitude Magnetic Bearing Centrifugal Chillers

TABLE 3

Building Code: CBC 2016 Seismic Certification Limits: $S_{DS} = 2.0 \text{ g} \quad z/h = 1.0$ $S_{DS} = 2.5 \text{ g} \quad z/h = 0.0$

Manufacturer	Model	Description		
	Modet	Description Description	Notes	UUT
	M7-092Y	450hp, 380V - 480V, Al shell 32.91"d x 44.85"w x 24.5"h, 961 lbs.		4
D 11:	M7-092X	450hp, 380V - 480V, Al shell 32.91"d x 44.85"w x 24.5"h, 961 lbs.		Interp
Daikin	M9=106Y	600hp, 380V - 480V, Al shell 35.21"d x 44.95"w x 25.19"h, 1118 lbs.	Permanent Magnet	Interp
	M9-106X	600hp, 380V - 480V, Al shell 35.21"d x 44.95"w x 25.19"h, 1118 lbs.		4
PSI	FRN0520E2S-4UDA-220C	20.87"d x 57.75"w x 57.75"H, 1155 lbs.		4
	FRN0590E2S-4UDA-280C	20.87"d x 57.75"w x 57.75"H, 1155 lbs.		Interp
	FRN0650G1S-4UDA-315C	20.87"d x 62.5"w x 62.13"H <mark>, 1155</mark> lbs.		Interp
	FRN0740G1S-4UDA-355C	20.87"d x 62.5"w x 62.13"H, 1155 lbs.		Interp
	FRN160VG1S-4UDA-160C	20.87"d x 85"w x 57.5"H, 1575 lbs.		Interp
	FRN200VG1S-4UDA-200C	20.87"d x 85"w x 57.5"H, 1575 lbs.		Interp
	FRN220VG1S-4UDA-220C	20.87"d x 85"w x 57.5"H, 1575 lbs.		4
PSI	Part 331346712	MicroTech, Siemens/PC based 8.9"d x 18.2"w x 25"h, 79 lbs.	Unit Controller	4
Benshaw/Carel	Part 332830705	MicroTech II, Carel based, Carbon Steel 8.9"d x 16"w x 32.8"h, 75 lbs.	Unit Controller	3
AxiomTech	Part 331670401	OITS, 21" Touch Screen, Plastic 2.2"d x 20.7"w x 12.6"h, 6.4 lbs.		3,4
<u>-</u>	PSI Benshaw/Carel	Daikin M9-106Y M9-106X FRN0520E2S-4UDA-220CT FRN0590E2S-4UDA-280C FRN0650G1S-4UDA-315C FRN160VG1S-4UDA-355C FRN160VG1S-4UDA-160C FRN200VG1S-4UDA-200C FRN220VG1S-4UDA-220C PSI Part 331346712 Benshaw/Carel Part 332830705	## Daikin M7-092Y A50hp, 380V - 480V, Al shell 32.91"d x 44.85"w x 24.5"h, 961 lbs. 450hp, 380V - 480V, Al shell 32.91"d x 44.85"w x 24.5"h, 961 lbs. 450hp, 380V - 480V, Al shell 32.91"d x 44.85"w x 24.5"h, 961 lbs. 600hp, 380V - 480V, Al shell 35.21"d x 44.95"w x 25.19"h, 1118 lbs. 600hp, 380V - 480V, Al shell 35.21"d x 44.95"w x 25.19"h, 1118 lbs. FRN0520E2S-4UDA-220C"	Daikin M7-092Y 450hp, 380V - 480V, Al shell 32.91"d x 44.85"w x 24.5"h, 961 lbs. M7-092X 450hp, 380V - 480V, Al shell 32.91"d x 44.85"w x 24.5"h, 961 lbs. M9-106Y 600hp, 380V - 480V, Al shell 35.21"d x 44.95"w x 25.19"h, 1118 lbs. 600hp, 380V - 480V, Al shell 35.21"d x 44.95"w x 25.19"h, 1118 lbs. FRN0520E2S-4UDA-220C 20.87"d x 57.75"w x 57.75"H, 1155 lbs. FRN0650G1S-4UDA-315C FRN0650G1S-4UDA-315C 20.87"d x 62.5"w x 62.13"H, 1155 lbs. FRN160VG1S-4UDA-160C FRN200VG1S-4UDA-200C FRN200VG1S-4UDA-200C FRN200VG1S-4UDA-220C 20.87"d x 85"w x 57.5"H, 1575 lbs. FRN20VG1S-4UDA-220C 20.87"d x 85"w x 57.5"H, 1575 lbs. FRN20VG1S-4UDA-220C 20.87"d x 85"w x 57.5"H, 1575 lbs. PSI Part 331346712 MicroTech, Siemens/PC based 8.9"d x 18.2"w x 25"h, 79 lbs. Unit Controller Unit Controller Part 332830705 AxiomTech Part 331670401 OITS, 21" Touch Screen, Plastic





Manufactur Model Line:	· ·	Bearing Centrifugal Chillers				
UUT	Unit Description	Report Number	Testing Laboratory	S _{DS}	z/h	I _P
3	WMC060DC/E3009- HB2CL2V/C2609-GB2CL2V	15046-TR-001, Rev. 0	PEER Laboratory, UC Berkeley	2.0	1.0	1.5
4	WME099BD/E4216- YE2CR2V/C4216-JB2CR2V	1700688-TR-001 R0	ERDC-CERL	2.0	1.0	1.5
	TEZCRZV/C4Z10-JBZCRZV			2.5	0.0	
		TOR CODE				
	6	OSHPD	COMP			
	EI EI	OSP-0601-10	, E			
	0	BY:Timothy J. Pi	land O			
	CAL	DATE: 05/07/201	9 70			
	The state of the s	Pop All	- N [©] /			
		BUILDING	COL			
			TDII Compliance by Struct			

TRU Compliance, by Structural Integrity Associates, Inc. 844-TRU-0200 | info@trucompliance.com

TRU PROJECT NO. 1700688



UUT3

Manufacturer: Daikin Applied

Model Line: Magnitude Magnetic Bearing Centrifugal Chillers

WMC060DC/E3009-HB2CL2V/C2609-GB2CL2V **Serial Number:** 517A000900

Product Construction Summary:

Carbon Steel

Model Number:

Options/Subcomponent Summary:

WMC060D with E3009 Evaporator, C2609 Condenser, Dual Danfoss TT700 Compressors, MicroTech II Unit Controller in Benshaw Enclosure (Part 332830705), Power Panel in Benshaw Enclosure (Part BOX-ELEC,BEN-WMC_350D_C_TT700_01640_TT700_01640_D_00460_H6_A_S_D_N_N_S_N_N_N_S_RA), Tru-Vu 21" Interface (Part 331670401)

			UUT Pro	perties						
Weight		Di <mark>mensio</mark> n (in)	UD1	IFU		Lowes	t Natural	Frequen	cy (Hz)	
(lb)	Depth	Width	Height		Front-Back		Side-Side		Vertical	
9,555	168.5	168.5 55.2 9			14.2		14.3		12.8	
		UUT Highest	Passed Se	ismic Run	Informa	tion				
Buildi	ng Code	S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)		
CBC 2016		CICC-ES AC156 (2015)		2.0	1.0	1.50	3.2 2.4	1.67 0.67	0.67	
CBC	, 2010	DATI	2013) / (7/22501	9 0.0	1.5	3.2	2.4	1.07	0.67

Test Mounting Details:



Unit was rigid base mounted to the table using (8) 1" diameter SAE Grade 8 bolts and a 1/4" ribbed neoprene pad under each mounting foot.

Unit maintained structural integrity and remained functional per manufacturer requirement.

Contents were included in testing per operating conditions.

TRU PROJECT NO. 1700688



UUT 4

Manufacturer: Daikin Applied

Model Line: Magnitude Magnetic Bearing Centrifugal Chillers

Model Number: WME099BD/E4216-YE2CR2V/C4216-JB2CR2V Serial Number:

Product Construction Summary:

Carbon Steel

Options/Subcomponent Summary:

WME099BD/E4216-YE2CR2V/C4216-JB2CR2V with E4216 Evaporator, C4216 Condenser, Daikin 092Y and 106X Dual Compressors, Daikin M7 and M9 dual motors (450hp and 600hp), FRN0520E2S-4UDA and FRN220VG1S-4UDA Dual VFD Starters, PSI MicroTech Controller (Part 331346712), Tru-Vu 21" Interface (Part 331670401), Daikin Seismic Kit (Part 910268269)

UUT Properties VIII Properties											
Weight		Lowest Natural Frequency (Hz)									
(lb)	Depth	Width	Height	Fron	Front-Back		Side-Side		tical		
48,490	252	252 116		5	5.97		5.57		16.47		
		UUT Highest F	Passed Seismic Rui	n Informa	tion						
Buildi	ng Code	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)				
CBC 2016		OCC ES AC1EG/3	2.0	1.0	1 =	3.2	2.4	1.67	0.67		
CBC	. 2010	CICC-ES AC156 (2	2013/5 / 0 7 /2250 1	9 0.0	1.50	3.2 2.4		1.07	0.67		

Test Mounting Details:





UUT4 was base mounted to the table fixture using (8) 1" diameter SAE Grade 8 bolts and a 3/8" ribbed neoprene pad under each mounting foot. The fixture was mounted to the table using (36) 1-1/4" diameter SAE Grade 8 bolts.

Unit maintained structural integrity and remained functional per manufacturer requirement.

Contents were included in testing per operating conditions.

TRU PROJECT NO. 1700688




Manufacturer: Daikin Applied


Model Line: Magnitude Magnetic Bearing Centrifugal Chillers

WME099BD/E4216-YE2CR2V/C4216-JB2CR2V Model Number: Serial Number: **UUT 4**

A door closure mechanism were added to the electrical cabinets. Please see the Daikin Seismic Drawing below for more details. Daikin (Part 910268269)



The electrical cabinets were braced using (3) 0.1<mark>88" L-</mark> shaped carbon steel braces. The cabi<mark>nets w</mark>ere restrained to each other using a 0.188" carbon steel: Tir plate fastened using (4) existing eye hooks. Please see the Daikin Seismic Drawings (RH Bracket- Drawings 1 & 6-11 and LH Bracket-Drawings 3 & 11) for more details including material and dimensions. Daikin (Part 910268269)






(3) 0.188" L-Shaped

Steel Braces



The large electrical cabinet was stiffened using a 1-5/8" x 87" 12ga galvanized carbon steel Unistrut fasten with (6) preexisting bolts. Please see the Daikin Seismic Drawings 4 & 12 for more details including material and dimensions. Daikin (Part 910268269)




TRU PROJECT NO. 1700688




Manufacturer: Daikin Applied **UUT 4 Model Line:** Magnitude Magnetic Bearing Centrifugal Chillers WME099BD/E4216-YE2CR2V/C4216-JB2CR2V Model Number: Serial Number: **Modification Drawing Key and RH Bracket-Drawing 1** PRODUCT ME & QE K C C RPC S (v) INITIAL RELEASE DETAIL A
EXPLODED VIEW (2) PLACES **DESCRIPTION:** INSTR,ASSY,SEISMIC BRACKETS,WME106E48C42,S6 of 3 DAIKIN **DETAIL B** (2) PLACES 910259213 Materials and Dimensions referenced in Drawing 6 - 11









TRU Compliance, by Structural Integrity Associates, Inc. 844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHEET

IRU PROJECT NO. 1700688

COMPLIANCE

