



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION

APPLICATION FOR OSHPD SPECIAL SEISMIC
CERTIFICATION PREAPPROVAL (OSP)

OFFICE USE ONLY

APPLICATION #: OSP – 0640

OSHPD Special Seismic Certification Preapproval (OSP)

Type: ☒ New ☐ Renewal

Manufacturer Information

Manufacturer: Vertiv

Manufacturer's Technical Representative: Keith Goshia

Mailing Address: 975 Pittsburgh Drive, Delaware, OH 43015

Telephone: (740) 833-8557

Email: keith.goshia@vertiv.com

Product Information

Product Name: Liebert EXS UPS

Product Type: Uninterruptible Power Supply OSP-0640

Product Model Number: Varies (See attachment)

(List all unique product identification numbers and/or part numbers)

General Description: UPS cabinets, seismic modifications made to address anomalies observed during tests shall be incorporated into the production units.

Mounting Description: Base mounted-rigid

Applicant Information

Applicant Company Name: TRU Compliance, by Structural Integrity Associates, Inc.

Contact Person: Galen Reid

Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138

Telephone: 844-878-0200


Email: greid@structint.com

I hereby agree to reimburse the Office of Statewide Health Planning and Development review fees in accordance with the California Administrative Code, 2016.

Signature of Applicant:  Date: 12/31/19

Title: Program Manager Company Name: TRU Compliance, by Structural Integrity Associates, Inc.

"Access to Safe, Quality Healthcare Environments that Meet California's Diverse and Dynamic Needs"





**OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT
FACILITIES DEVELOPMENT DIVISION**

California Licensed Structural Engineer Responsible for the Engineering and Test Report(s)

Company Name: TRU Compliance, by Structural Integrity Associates, Inc.

Name: Andrew M. Coughlin California License Number: S6082

Mailing Address: 5215 Hellyer Ave., Suite 210, San Jose, CA 95138

Telephone: 844-878-0200 Email: acoughlin@structint.com

Supports and Attachments Preapproval

- ☐ Supports and attachments are preapproved under OPM-
(Separate application for OSHPD Preapproval of Manufacturer's Certification (OPM) of Supports and attachments is required)
- ☒ Supports and attachments are not preapproved

Certification Method

- ☒ Testing in accordance with: ☒ ICC-ES AC156
- ☐ Other (Please Specify): _____

Testing Laboratory

Company Name: Environmental Testing Laboratory

Contact Name: Jeremy Lange

Mailing Address: 11034 Indian Trail, Dallas, TX 75229

Telephone: (972) 247-9657 Email: jeremy@etldallas.com



OFFICE OF STATEWIDE HEALTH PLANNING AND DEVELOPMENT FACILITIES DEVELOPMENT DIVISION

Seismic Parameters

Design in accordance with ASCE 7-10 Chapter 13: ☒ Yes ☐ No

Design Basis of Equipment or Components (F_p/W_p) = 1.12 ($S_{DS} = 1.55$, $z/h = 1$); 1.01 ($S_{DS} = 2.25$, $z/h = 0$)

S_{DS} (Design spectral response acceleration at short period, g) = 1.55 ($z/h = 1$), 2.25 ($z/h = 0$)

a_p (In-structure equipment or component amplification factor) = 1.0

R_p (Equipment or component response modification factor) = 2.5

Ω_0 (System overstrength factor) = 2.0

I_p (Importance factor) = 1.5

z/h (Height factor ratio) = 1 ($S_{DS} = 1.55$), 0 ($S_{DS} = 2.25$)

Equipment or Component Natural Frequencies (Hz) = See Attachment

Overall dimensions and weight (or range thereof) = See Attachment

Equipment or Components @ grade designed in accordance with ASCE 7-10 Chapter 15: ☐ Yes ☒ No

Design Basis of Equipment or Components (V/W) = _____

S_{DS} (Design spectral response acceleration at short period, g) = _____

S_{D1} (Design spectral response acceleration at 1 second period, g) = _____

R (Response modification coefficient) = _____

Ω_0 (System overstrength factor) = _____

C_d (Deflection amplification factor) = _____

I_p (Importance factor) = 1.5

Height to Center of Gravity above base = _____

Equipment or Component Natural Frequencies (Hz) = _____

Overall dimensions and weight (or range thereof) = _____

Tank(s) designed in accordance with ASME BPVC, 2015: ☐ Yes ☒ No

List of Attachments Supporting Special Seismic Certification

☒ Test Report(s) ☐ Drawings ☐ Calculations ☒ Manufacturer's Catalog

☒ Other(s) (Please Specify): Product Matrices

OSHPD Approval (For Office Use Only) – Approval Expires on December 31, 2025

Signature: William Staehlin

Date: May 13, 2021

Print Name: William Staehlin

Title: Senior Structural Engineer

Special Seismic Certification Valid Up to: S_{DS} (g) = See Above

z/h = See Above

Condition of Approval (if applicable): _____

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1900510-CR-001 R2



Manufacturer: Vertiv Corporation						TABLE 1	
Model Line: Liebert EXS UPS							
Certified Product Construction Summary: Carbon steel frame and skins							
Certified Options Summary: 10, 15, 20 and 30 kVA/kW, 208/220V, Three-Phase Tower							
Mounting Configuration (Standalone): Base mounted - rigid Note: Installed mounting configuration must be of similar configuration and equivalent strength and stiffness to those tested.							
Building Code:		CBC 2019		Seismic Certification Limits:		$S_{DS}= 1.55\text{ g}\quad z/h=1.0$ $S_{DS}= 2.25\text{ g}\quad z/h=0.0$ $I_P= 1.5$	
Model Line	Model	Dimensions (in)			Weight (lb)	Notes	UUT
		Depth	Width	Height			
EXS Frame 1 10 kVA	53S10AC1AXXXXX	25.6	13.2	51.2	437	1 battery string	Extrap.
		Extrap.
	53S10EC2A0B0052	25.6	13.2	51.2	627.5	2 battery strings	1
EXS Frame 1S with Extended Battery 10 kVA	53S10AC3AXXXXX	25.6	22.7	51.2	893	3 battery strings	Interp.
		Interp.
	53S10FC4A0A0052	25.6	22.7	51.2	1128.5	4 battery strings	2
EXS Frame 2 15-20 kVA	53S15GC2B0XXXX	29.5	17.3	63	734	Identical to EXS 20kVa, software	Interp.
	53S15AG3AXXXXX	29.5	17.3	63	888		Interp.
	53S15GC4AXXXXX	29.5	17.3	63	1042		Interp.
	53S20GC6A0000CB	29.5	17.3	63	767.5	2 battery strings	3
	53S20GCXAXXXXXX	29.5	17.3	63	888		Interp.
	53S20GC8A0C00CO	29.5	17.3	63	1124.5	4 battery strings	4
EXS Fame 3 30 kVA	53S30HCERXXXXXX	23.6	33.5	63	1162	1 battery string	Interp.
	53S30HCFR000CST	23.6	33.5	63	1581	2 battery strings	5
EBC Frame 3	53BP30H11L1	23.6	33.5	63	870	1 battery string	7
	53BP30H12L1	23.6	33.5	63	1376	2 battery strings	6

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

1900510-CR-001 R2



TRU Compliance, by Structural Integrity Associates, Inc.
844-TRU-0200 | info@trucompliance.com

SPECIAL SEISMIC CERTIFICATION CERTIFIED COMPONENT MATRIX

1900510-CR-001 R2



Manufacturer: Vertiv Corporation
Model Line: Liebert EXS UPS

TABLE 3

EXS Nomenclature

1-2	3	4-5	6	7	8	9	10	11	12	13-15
Product Line	System Type	Nameplate Rating	Frame Type	Input & Output Voltage	Battery String Qty & No. of Jars/String	Battery Model Code	Factory installed Communication Cards ^{1,2}	Factory Installed Distribution Slot 1	Factory Installed Distribution Slot 2 ³	Config Digits
53 = Liebert EXS	S = Single Module	10 = 10kVA/10kW 15 = 15kVA/15kW 20 = 20kVA/20kW 30 = 30kVA/30kW	A = Frame 1 335mm, 10kA B = Frame 1S 570mm, 10kA E = Frame 1 335mm, 30kA F = Frame 1S 570mm, 30kA G = Frame 2 440mm, 30kA H = Frame 3 600mm, 30kA	C = 208/120 in 208/120 out Y = 220/127 in 220/127 out	10 = None 1 = 1 String - 32 Jars 2 = 2 Strings - 32 Jars 3 = 3 Strings - 32 Jars 4 = 4 Strings - 32 Jars 5 = 5 Strings - 28 Jars 6 = 6 Strings - 28 Jars 7 = 7 Strings - 28 Jars 8 = 8 Strings - 20 Jars 9 = 9 Strings - 20 Jars H = 4 Strings - 20 Jars	0 = No Battery A = CSB HRL1234WF2FR R = CSB HRL12150WFR	0 = IS-UNITY-LIFE / None 1 = IS-UNITY-SNMP / None 2 = IS-UNITY-DP / None 3 = IS-UNITY-LIFE / IS-RELAY 4 = IS-UNITY-LIFE / IS-485EXI 5 = IS-UNITY-SNMP / IS-RELAY 6 = IS-UNITY-SNMP / IS-485EXI 7 = IS-UNITY-DP / IS-RELAY 8 = IS-UNITY-DP / IS-485EXI A = IS-UNITY-DP / IS-UNITY-DP B = IS-UNITY-DP / IS-UNITY-SNMP C = IS-UNITY-SNMP / IS-UNITY-SNMP D = IS-485EXI / None E = IS-485EXI / IS-RELAY	These characters are shared for digits 11 & 12: 0 = None A - (2) L21-30R [PD3-001] B - (6) L6-30R [PD3-002] C - (6) L5-30R [PD3-003] D - (1) IEC60309 3W [PD3-004] E - (6) L5-20R [PD3-005] F - (6) L6-20R [PD3-006] G - (2) L15-30R [PD3-007] H - (1) CS8365C [PD3-008] J - (2) L21-20R [PD3-009] K - (2) L15-20R [PD3-010] L - (1) IEC60309 4W [PD3-011] 1 = (2) L6-30R, (8) 5-15/20R, [PD2-101] 2 = (4) L6-20R, (4) 5-15/20R, [PD2-102] 3 = (4) L6-30R, (4) 5-15/20R, [PD2-103] 4 = (2) L6-30R, (2) L6-20R, (4) 5-15/20R, [PD2-104] 5 = (2) L5-30R, (2) L5-20R, (4) 5-15/20R, [PD2-105] 6 = (4) L6-20R, (4) L5-20R, [PD2-106] 7 = (4) L5-20R, (4) 5-15/20R, [PD2-107] 8 = (2) L6-30R, (2) L6-20R, [PD2-108] 9 = (2) L14-30R, [PD2-109] W = (4) IEC320-C19, (4) IEC320-C13, [PD2-200] X = (2) IEC320-C19, (8) IEC320-C13, [PD2-201] Y = (12) IEC320-C13, [PD2-202] Z = (2) IEC320-32A, (4) IEC320-C13, [PD2-204]		Unique Number Automatic Assigned

SPECIAL SEISMIC CERTIFICATION CERTIFIED SUBCOMPONENT MATRIX

1900510-CR-001 R2



Manufacturer: Vertiv Corporation		Table Description: Subcomponents					TABLE 4			
Model Line: Liebert EXS UPS										
Building Code: CBC 2019		Seismic Certification Limits:					$S_{DS} = 1.55\text{ g} \quad z/h = 1.0$ $S_{DS} = 2.25\text{ g} \quad z/h = 0.0$		$I_p = 1.5$	
Model Line (Manufacturer)	Model	Dimension (in)			Weight (lb)	Material	Notes	UUT		
		Depth	Width	Height						
Battery (CBS)	HRL123W-F2FR	2.6	6	3.7	6	Lead Acid		1,2,3,4,5		
	HRL12150W-FR	7.7	5.12	6.8	26.5	Lead Acid		6,7,8		
Battery (Data Safe)	12HX150	7.68	5.12	6.46	22.5	Lead Acid		8		
Bypass /Maintenance Isolation Breaker (ABB)	S203-C40	2.1	2.7	3.5	0.8	Plastic		1,2,3		
Maintenance Bypass Breaker (ABB)	S203-C50	2.1	2.7	3.5	0.8	Plastic		1,2,3		
2925.5	S204-C40	2.8	2.7	3.5	1.1	Plastic		1,2,3		
Breaker (NADER)	NDM1-125C80/3	2.8	2.7	3.5	1.2	Plastic		4,5		
	NDM1-125C125/3	2.8	2.7	3.5	1.2	Plastic		8		
Breaker (Siemens)	3VA5217-5EC31-0AA0	4.2	4.1	7.3	4.5	Plastic		6,7,8		
Communication Cards (Liebert)	IS-UNITY-LIFE		3	1.5	0.44	Carbon steel and plastic		1,2		
	IS-UNITY-SNMP		3	1.5	0.44			3		
	IS-UNITY-DP		3	1.5	0.44			4		
	IS-RELAY		3	1.5	0.44			5,6		
	IS-485EXI		3	1.5	0.44			5,6		

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

1900510-CR-001 R2



TRU Compliance, by Structural Integrity Associates, Inc.
844-TRU-0200 | info@trucompliance.com
Page 8 of 17

1900510-CR-001 R2



TRU Compliance, by Structural Integrity Associates, Inc.
844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHEET



1900510-CR-001 R2

Manufacturer:	Vertiv Corporation	UUT 1
Model Line:	Liebert EXS UPS	
Model Number:	53S10EC2A0B0052	
		Serial Number: M19GBE0002

Product Construction Summary:

Carbon steel frame and skin

Options/Subcomponent Summary:

Battery - CBS (PN: HRL123W-F2Fr, Bypass/Maintenance Isolator Breaker - ABB: S203-C40, Maintenance Bypass Breaker - ABB: S203-C50, Rectifier Input Breaker-ABB: S204-C40, Communication Card-Vertiv: IS-UNITY-LIFE, Power Output Distribution-Vertiv: PD3-002

UUT Properties

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
627.5	25.6	13.2	51.2	13.84	10.59	22.50

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2019	ICC-ES AC156 (2018)	1.55	1.0	1.5	2.48	1.86	1.50	0.60
		2.25	0.0					

Test Mounting Details:



UUT base mounted rigid to shake table with mounting brackets at the front and rear base of unit. Each mounting bracket (Vertiv PN: 660267P1) was attached to the unit with (4) 3/8" Grade 5 bolts and to the shake table with (3) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHEET



1900510-CR-001 R2

Manufacturer:	Vertiv Corporation	UUT 2
Model Line:	Liebert EXS UPS	
Model Number:	53S10FC4A0A0052	
		Serial Number: M19GBE0003

Product Construction Summary:
Carbon steel frame and skin, sidecar battery

Options/Subcomponent Summary:
Battery - CBS (PN: HRL123W-F2Fr, Bypass/Maintenance Isolator Breaker - ABB: S203-C40, Maintenance Bypass Breaker - ABB: S203-C50, Rectifier Input Breaker-ABB: S204-C40, Communication Card-Vertiv: IS-UNITY-LIFE, Power Output Distribution-Vertiv: PD3-001

UUT Properties										
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)						
	Depth	Width	Height	Front-Back		Side-Side		Vertical		
1128.5	25.6	22.7	51.2	8.62		11.01		28.40		
UUT Highest Passed Seismic Run Information										
Building Code		Test Criteria		S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2019		ICC-ES AC156 (2018)		1.55	1.0	1.5	2.48	1.86	1.50	0.60
				2.25	0.0					

Test Mounting Details:



UUT base mounted rigid to shake table with mounting brackets at the front and rear base of unit. Each mounting bracket (Vertiv PN: 660130P1 & 660130P2) attached to the shake table with (4) 3/8" Grade 5 bolts and to the unit with (4) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers.
Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.
Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET



1900510-CR-001 R2

Manufacturer:	Vertiv Corporation	UUT 3
Model Line:	Liebert EXS UPS	
Model Number:	53S20GC6A0000CB	
Serial Number:		M19GB00002

Product Construction Summary:
Carbon steel frame and skins, 2 battery string

Options/Subcomponent Summary:
Battery - CBS (PN: HRL123W-F2Fr, Bypass/Maintenance Isolator Breaker - ABB: S203-C40, Maintenance Bypass Breaker - ABB: S203-C50, Rectifier Input Breaker-ABB: S204-C40, Communication Card-Vertiv: IS-UNITY-SNMP

UUT Properties										
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)						
	Depth	Width	Height	Front-Back		Side-Side		Vertical		
767.5	29.5	17.3	63	11.52		5.92		>33.3		
UUT Highest Passed Seismic Run Information										
Building Code		Test Criteria		S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2019		ICC-ES AC156 (2018)		1.55	1.0	1.5	2.48	1.86	1.50	0.60
				2.25	0.0					

Test Mounting Details:



UUT base mounted rigid to shake table with mounting brackets at the front and rear base of unit. Each mounting bracket (Vertiv PN: 660224P1) was attached to the unit with (4) 3/8" Grade 5 bolts and to the shake table with (4) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET



1900510-CR-001 R2

Manufacturer:	Vertiv Corporation	UUT 4
Model Line:	Liebert EXS UPS	
Model Number:	53S20GC8A0C00CO	
Serial Number:		M19GB00003

Product Construction Summary:
Carbon steel and skin - 4 battery string

Options/Subcomponent Summary:
Battery - CBS (PN: HRL123W-F2Fr, Breaker-Nader: NDM1-125C80/3 Communication Card-Vertiv: IS-UNITY-DP, Power Output Distribution-Vertiv: PD3-003

UUT Properties										
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)						
	Depth	Width	Height	Front-Back	Side-Side	Vertical				
1124.5	29.5	17.3	63	9.06	3.79	19.96				
UUT Highest Passed Seismic Run Information										
Building Code		Test Criteria		S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2019		ICC-ES AC156 (2018)		1.55	1.0	1.5	2.48	1.86	1.50	0.60
				2.25	0.0					

Test Mounting Details:



UUT base mounted rigid to shake table with mounting brackets at the front and rear base of unit. Each mounting bracket (Vertiv PN: 660224P1) was attached to the unit with (4) 3/8" Grade 5 bolts and to the shake table with (4) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET



1900510-CR-001 R2

Manufacturer:	Vertiv Corporation	UUT 5
Model Line:	Liebert EXS UPS	
Model Number:	53S30HCFR000CST	
		Serial Number: M19GBE008

Product Construction Summary:

Carbon steel frame and skin

Options/Subcomponent Summary:

Battery - CBS (PN: HRL123W-F2Fr, Breaker-Nader: NDM1-125C80/3, Communication Card-Vertiv: IS-Relay, Communication Card-Vertiv: IS-485EXI, Output Distribution-Vertiv: PD2-102

UUT Properties

Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)		
	Depth	Width	Height	Front-Back	Side-Side	Vertical
1581	23.6	33.5	63	12.01	5.51	17.24

UUT Highest Passed Seismic Run Information

Building Code	Test Criteria	S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2019	ICC-ES AC156 (2018)	1.55 2.25	1.0 0.0	1.5	2.48	1.86	1.50	0.60

Test Mounting Details:



UUT base mounted rigid to shake table with mounting brackets at the front and rear base of unit. Each mounting bracket (Vertiv PN: 660224P1) was attached to the unit with (4) 3/8" Grade 5 bolts and to the shake table with (4) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Contents were included in testing per operating conditions.

TRU Compliance, by Structural Integrity Associates, Inc.

844-TRU-0200 | info@trucompliance.com

UNIT UNDER TEST (UUT) SUMMARY SHEET



1900510-CR-001 R2


Manufacturer:	Vertiv Corporation	UUT 6
Model Line:	Liebert EXS UPS	
Model Number:	53BP30H12L1	
Serial Number:		N/A

Product Construction Summary:
Carbon steel frame and skin, 2 Battery Strings

Options/Subcomponent Summary:
Battery - CBS: HRL12150W-FR, Battery-Data Safe: 12HX150, Breaker - Siemens: 3VA5217-5EC31-0AA0

UUT Properties										
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)						
	Depth	Width	Height	Front-Back		Side-Side		Vertical		
1376	23.6	33.5	63	11.21		6.44		22.20		
UUT Highest Passed Seismic Run Information										
Building Code		Test Criteria		S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2019		ICC-ES AC156 (2018)		1.55	1.0	1.5	2.48	1.86	1.50	0.60
				2.25	0.0					

Test Mounting Details:



UUT base mounted rigid to shake table with mounting brackets at the front and rear base of unit. Each mounting bracket (Vertiv PN: 660224P1) was attached to the unit with (4) 3/8" Grade 5 bolts and to the shake table with (4) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET



1900510-CR-001 R2

Manufacturer:	Vertiv Corporation	UUT 7
Model Line:	Liebert EXS UPS	
Model Number:	53BP30H11L1	
Serial Number:		N/A

Product Construction Summary:
Carbon steel frame and skin, 1 Battery String

Options/Subcomponent Summary:
Battery - CBS: HRL12150W-FR, Breaker - Siemens: 3VA5217-5EC31-0AA0

UUT Properties										
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)						
	Depth	Width	Height	Front-Back	Side-Side	Vertical				
870	23.6	33.5	63	15.61	7.27	22.33				
UUT Highest Passed Seismic Run Information										
Building Code		Test Criteria		S _{DS} (g)	z/h	I _p	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2019		ICC-ES AC156 (2018)		1.55	1.0	1.5	2.48	1.86	1.50	0.60
				2.25	0.0					

Test Mounting Details:



UUT base mounted rigid to shake table with mounting brackets at the front and rear base of unit. Each mounting bracket (Vertiv PN: 660224P1) was attached to the unit with (4) 3/8" Grade 5 bolts and to the shake table with (4) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers.

Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test.

Contents were included in testing per operating conditions.

UNIT UNDER TEST (UUT) SUMMARY SHEET



1900510-CR-001 R2

Manufacturer:	Vertiv Corporation	UUT 8
Model Line:	Liebert EXS UPS	
Model Number:	53BP30H21L1 & 53S30HCER000CST	
Serial Number:	M19GBE0007 & M19GBE0008	

Product Construction Summary:

Carbon steel frame and skin. Units ganged together and 4 Battery Strings.

Options/Subcomponent Summary:

Battery - CBS: HRL12150W-FR, Battery-Data Safe: 12HX150, Breaker - Siemens: 3VA5217-5EC31-0AA0, Breaker-Nader: NDM1-125C80/3, Communication Card-Vertiv: IS-Relay, Communication Card-Vertiv: IS-485EXI, Output Distribution-Vertiv: PD2-102

UUT Properties										
Weight (lb)	Dimension (in)			Lowest Natural Frequency (Hz)						
	Depth	Width	Height	Front-Back		Side-Side		Vertical		
2925.5	23.6	67	63	7.56		4.13		17.48		
UUT Highest Passed Seismic Run Information										
Building Code		Test Criteria		S _{DS} (g)	z/h	I _P	A _{FLX-H} (g)	A _{RIG-H} (g)	A _{FLX-V} (g)	A _{RIG-V} (g)
CBC 2019		ICC-ES AC156 (2018)		1.55	1.0	1.5	2.48	1.86	1.50	0.60
				2.25	0.0					

Test Mounting Details:



UUT ganged together with two M10 bolts at the front and back junction of the cabinets. UUT base mounted - rigid to table with four (4) brackets provided by manufacturer (Vertiv PN: 660224P1). Each mounting bracket was attached to the unit with (4) 3/8" Grade 5 bolts and to the shake table with (4) 3/8" Grade 5 bolts. All bolts used lock washers and flat washers. Unit maintained structural integrity and remained functional per manufacturer requirement after shake table test. Contents were included in testing per operating conditions.